


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County BARBER	Township name VALLEY	Fraction SE 1/4 SE	Section number 35	Town number 30 South	Range number 11 West
Distance and direction from nearest town or city: 3 1/2 mi - 1 mile North			3 Owner of well: TINA RATHME ZIP 67526			
Street address of well location if in city: 4 South of Nashville Kan			Address: ELENWOOD KANSAS			
Locate with "X" in section below: N W E S 1 Mile			Sketch map: 			4 Well depth: 63 ft. Date of completion 12-16 Well diameter 10 in.
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
			Sail	0	3	6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input checked="" type="checkbox"/> Stock Well
Sandy Brown			3	10	7 Casing: Material Steel Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 36 in. Dig. Weight 80 lbs./ft. galvanized 10 in. to 10 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No — in. to — ft. depth	
Sand and clay sandy			10	30	8 Screen: RED Head Manufacturer Madville Dia. 1.25 in Type Madville Dia. 1.25 in Slot/gauze 100 # Length 36" Set between 60 ft. and 63 ft. Fittings: Cement grout Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 3/8"	
Clay			30	50	9 Static water level: 55 ft. below land surface Date 12-16	
Sand gravel			60	63	10 Pumping level below land surface: — ft. after — hrs. pumping — g.p.m. — ft. after — hrs. pumping — g.p.m. Estimated maximum yield — g.p.m.	
Well Depth 63 feet clay Bottom Well					11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date 12-16	
					12 Well head completion: Domestic Pump Head <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade	
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 1 ft. to 10 ft.	
					14 Nearest source of possible contamination: ft. 100 Direction North Type Backyard Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Monitor Pump Co Model number 2492 HP 3/4 Volts 110 Length of drop pipe 63 ft. capacity ? g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input checked="" type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation					17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. WATERWELL SERVICE 226 Business name NASHVILLE Kan License No. Address NASHVILLE Kan Signed Loren Wilson Date 12-16 Authorized representative	

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5