

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

MT. JESUS
NW

DBD

1. Location of well:		County Clark	Fraction SE 1/4 NW 1/4 qse/4	Section number 8	Township number T 30	Range number S R 21W E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 8s Bucklin Ks.			3. Owner of well: R.R. or street: City, state, zip code: Gabbert-Jones Inc. 830 Sutton Pl Wichita, Ks. 67202			
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		6. Bore hole dia. 8 in. Completion date Well depth 142 ft. 3-21-78	
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Top Soil-Clay			0	60	9. Casing: Material _____ Height: Above or below _____ Threaded _____ Welded _____ Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 2.8 lbs./ft. Dia. 5 in. to 142 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. Sch 40	
Sand-Clay			60	90	10. Screen: Manufacturer's name Jetstream	
Sand			90	142	Type pyc Dia. 5" Slot/gauze 1/32" Length 40' Set between 102 ft. and 142 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8-3/4"	
					11. Static water level: _____ mo./day/yr. 80 ft. below land surface Date 3-21-78	
					12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 g.p.m.	
					13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
					14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
					15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite _____ Concrete _____ Depth: From 0 ft. to 10 ft.	
					16. Nearest source of possible contamination: oil ft. 50 Direction S Type Test Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kellys Waterwell Ser 186 Business name License No. Address R2 Great Bend, Ks. Signed Kelly Price Date 9-14-78 Authorized representative	
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		TOTD		2319 142 2177		

30
21W
E
-
8
CSE
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5