

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

B (center)

1. Location of well:	County Clark	Fraction 1/4 1/4 NW 1/4	Section number 12	Township number T 30 S R 21	Range number 21
2. Distance and direction from nearest town or city: 6 S 3 E		3. Owner of well: Red Tiger Drilling Co			
Street address of well location if in city: Bucklin, KS.		R.R. or street: 1720 KS State Bldg			
		City, state, zip code: Wichita, KS			
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map:		6. Bore hole dia. 7 in. Completion date 6-2-76 Well depth 170 ft.	
5. Type and color of material		From		To	
		Top Soil - Clay		0 55	
		Sand - Clay		55 120	
		Sand - Gravel		120 160	
		Clay		160 170	
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material <input type="checkbox"/> Height: <input checked="" type="checkbox"/> Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 4 in. to 170 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>	
				10. Screen: Manufacturer's name MPI Type: PVC Dia. 4 in. Slot/gauze 1/8 Length 40 Set between 130 ft. and 170 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 4/8 3/4	
				11. Static water level: <input type="checkbox"/> mo./day/yr. 75 ft. below land surface Date 6-2-76	
				12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 40 g.p.m.	
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>	
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: oil ft. 75 Direction S Type TEST Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				(Use a second sheet if needed)	
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kelly's Water Well Serv Business name R2 Great Bend, KS License No. <input type="checkbox"/> Address Kelly, Peter Date 6-10-76 Signed <input type="checkbox"/> Authorized representative		

Topography:
☐ Hill
☐ Slope
☒ Upland
☐ Valley

2324
160
2164

30 210 12 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5