

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

SIMMONS
CRITIK

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

ACC

1. Location of well: County Clark Fraction SW 1/4 SW 1/4 NE 1/4 Section number 10 Township number T 30 S Range number R 23 E			
2. Distance and direction from nearest town or city: 5.5 3/4 Kingsdown Street address of well location, if in city: 5.5 3/4 Kansas		3. Owner of well: Pyle Ranch R.R. or street: Kingsdown Kansas City, state, zip code:	
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: X 6. Bore hole dia. 5 1/2 in. Completion date 3-6-79 Well depth 160 ft.	
5. Type and color of material		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
From To		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Top Soil		9. Casing: Material <input type="checkbox"/> Height Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 1 1/2 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 160 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 200	
Brown Clay		10. Screens: Manufacture Plastics Type RMP Dia. 5 Slot/gauze 1/8 Length 20 Set between 140 ft. and 160 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft.	
Gravel		Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 X 3/4	
Brock 160		11. Static water level: 118 ft. below land surface Date 3-19-79 mo./day/yr.	
118		12. Pumping level below land surfaces: 128 ft. after 1 hrs. pumping 3 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 10 g.p.m.	
42 sal thrd		13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
ing		14. Well head completion: <input type="checkbox"/> Pitless adapter 16 Inches above grade	
(Use a second sheet if needed)		15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.	
2430		16. Nearest source of possible contamination: ft. Cattle Direction E Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
1300		17. Pump: Manufacturer's name Windmill Not installed Model number Windmill HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
1170		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carl Hays Water Well Dr. 224 Business address 603 Maple St. Cambridge, Mo License No. 100 Signed Carl Hays Date 3-6-79 Authorized representative	
18. Elevation:		19. Remarks:	
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		2430 1300 1170	

30
23
10
1/4
1/4
1/4
1/4
SUSINE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5