USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD KSA 82a-1201-1215

D

SIMMONS KO

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

280' north of center County Fraction Section number Township number Range number 1. Location of well: 18 Clark 1/4 **SE** 1/4 30 23 1/4 E/W 2. Distance and direction from nearest town or city: 3. Owner of well: Gary Esplund 3-3/4 south Bloom, Kansas Street address of well location if in city: R.R. or street: RFD Star Rt. City, state, zip code: Kinneola, Kansas 6. Bore hole dia. 169 in. Completion date - 7-2-79 4. Locate with "X" in section below: Sketch map: 7. __ Cable tool __ Rotary __ Driven __ Dug __ Hollow rod __ Jetted __ Bored __ Reverse rotary - NW 8. Use: __ Domestic __ Public supply __ Industry Mile W Irrigation __ Air conditioning __ Stock ___ Lawn _ Oil field water __ Other 9. Casing: Material **Beta** Height: Above or below Dia. 16 in. to 169 ft. depth Wall Thickness: inches or Dia. __ in. to ___ ft. depth gage No. _ 188 _ 1 Mile -5. Type and color of material From 10. Screen: Manufacturer's name _ Topsoil 2 0 Type 175 Free-flo Dia. 16
Slot/gauze 1/8 Length
Set between 109 ft. and 16 Clay Gravel (dry) 40. 23 CLEY ft. and ... 103 Gravel pack? XCE Size range of material Rock and clay 103 110 11. Static water level: mo./day/yr. 119 ft. below land surface Date Gravel 110 161 Shale "----161 170 12. Pumping level below land surfaces: 155 ft. after 2 hrs. pumping _____ ft. after _____ hrs. pumping _ ___ g.p.m. ROCK 15+ _g.p.m. 13. Water sample submitted: mo./day/yr. Yes X No Date 119 St. 2.2.2 14. Well head completion: ____ Pitless adapter Inches above grade 15. Well grouted? Yes With:____ Neat sement ____ Bentonite ____ Concrete _ ft. to _**10**_ ft. 16. Nearest source of possible contamination: ft. _____ Direction ____ Type _ Well disinfected upon completion? _____ Yes ____ No Not installed Manufacturer's name _ ___ HP _____ Volts . Model number _____ Length of drop pipe _____ ft. capacity ____g.p.m. Type: ___ Submersible Turbine ____ Jet ___ Reciprocating (Use a second sheet if needed) _ Centrifugal Other 18. Elevation: 19. Remarks: 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report Didn't know who or if pump had been set is true to the best of my knowledge and belief Ace-Hi International Topography: __ Hill Business name License No. 2 PS Address Bodge City _ Slope X___ Upland _ Valley