USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	CLARK	NW1/4 NW1/4 NW1/4	10	T 30 S	R 25 (W)

2. Distance and direction from nearest town or city: 1 3/4 W Minneola 3/4 m N
Street address of well location if in city:

3. Owner of well: F L TEDFORD
R.R. or street:
City, state, zip code: Minneola Kansas

4. Locate with "X" in section below: Sketch map:

N
NW NE
W E
SW SE
S
1 Mile
1 Mile

6. Bore hole dia. 9 in. Completion date 11/19/80
Well depth 140 ft.

7. __ Cable tool X Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored __ Reverse rotary

8. Use: __ Domestic __ Public supply __ Industry
__ Irrigation __ Air conditioning __ Stock
__ Lawn X Oil field water __ Other

9. Casing: Material PVC Height: Above or below
Threaded ___ Welded ___ Surface 14 in.
RMP ___ PVC glued Weight ___ lbs./ft.
Dia. 5 in. to 65 ft. depth Wall Thickness: inches or
Dia. ___ in. to ___ ft. depth gage No. 0258

5. Type and color of material	From	To
Overburden	0	65
Medium to coarse sand	65	100
Coarse sand + clay	100	135
Blue clay	135	140

(Use a second sheet if needed)

10. Screen: Manufacturer's name PEERLESS
Type PVC Dia. 5"
Slot/gauze 1/16 Length 80'
Set between 60 ft. and 140 ft.
___ ft. and ___ ft.
Gravel pack? yes Size range of material 1/8

11. Static water level: mo./day/yr.
65 ft. below land surface Date 11/19/80

12. Pumping level below land surfaces:
___ ft. after ___ hrs. pumping ___ g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield 50 g.p.m.

13. Water sample submitted: mo./day/yr.
__ Yes X No Date

14. Well head completion:
__ Pitless adapter 14 Inches above grade

15. Well grouted? yes
With: X Neat cement __ Bentonite __ Concrete
Depth: From 3 ft. to 13 ft.

16. Nearest source of possible contamination:
ft. ___ Direction ___ Type ___
Well disinfected upon completion? ___ Yes ___ No

17. Pump: __ Not installed
Manufacturer's name Goulds
Model number V7M5GU HP 5 Volts 230
Length of drop pipe 100 ft. capacity 50 g.p.m.
Type:
X Submersible __ Turbine
__ Jet __ Reciprocating
__ Centrifugal __ Other

18. Elevation:

Topography:
__ Hill
__ Slope
X Upland
__ Valley

19. Remarks:
16" well drilled in pasture
17. pumped well 14 days - pulled pump - capped well

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
T-W Water Well Service 142
Business name License No.
Address Box 816 Liberal, Ks 67901
Signed [signature] Date 11/28/80
Authorized representative

T ___ R ___ W ___ Sec ___ 1/4 ___ 1/4 ___ 1/4 ___

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5