


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Meade	Fraction NE 1/4 NE 1/4 SE 1/4	Section number 22	Township number T 30 S R 27 E W	Range number 27
2. Distance and direction from nearest town or city: 3 west and 2 1/2 north of Fowler, Ks Street address of well location if in city:				3. Owner of well: Zortman & Sons R.R. or street: RFD City, state, zip code: Fowler, Kansas		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 28 in. Completion date 6-25-79 Well depth 304 ft.		
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other <input type="checkbox"/>		
Surface		0	3	9. Casing: Material metal Height: Above or below		
Brown clay		3	22	Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in.		
White and brown clay		22	28	RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft.		
Fine sand		28	36	Dia. 16 in. to <input type="checkbox"/> ft. depth Wall Thickness: inches or		
Gray clay		36	41	Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219		
Fine to med. sand		41	54	10. Screen: Manufacturer's name W.A. Brown & Cook		
Gray and lite brown clay		54	77	Type Brown 174-Cook Dia. 100 slot 16"		
Fine sand and clay streaks		77	88	Slot/gauze 1/8 & 100 Length 270		
Gray, yellow and dark brown clay with fine sand		88	114	Set between 34 ft. and 304 ft.		
Fine sand and clay layers		114	157	Cook 174 ft. and 184 ft.		
Fine to med. sand		157	168	Gravel pack? yes Size range of material 5/8 to 1 1/2"		
Clay		168	169	11. Static water level: NA ft. below land surface Date 2-15-80		
Med. sand and gravel		169	188	12. Pumping level below land surfaces: NA		
Med. sand		188	204	ft. after <input type="checkbox"/> hrs. pumping NA g.p.m.		
Gray and blue clay with rock layers		204	219	160 ft. after 2 hrs. pumping 1610 g.p.m.		
Sandy clay and fine sand layers		219	245	Estimated maximum yield NA 6000 g.p.m.		
Fine to med. sand		245	256	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
Sandy clay		256	263	14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
Sandy clay and sandrock with 30% fine sand		263	280	15. Well grouted? yes		
Fine sand with 30% sandrock		280	293	With: Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete <input type="checkbox"/>		
Yellow, gray and blue clay		293	327	Depth: From 0 ft. to 10 ft.		
Blue shale with rock stringers		327	340	16. Nearest source of possible contamination: 100 west ft. 100 Direction west Type well		
				Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed		
				Manufacturer's name <input type="checkbox"/>		
				Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/>		
				Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m.		
				Type:		
				<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine		
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating		
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ace-Hi International 190 Business name License No. Address Dodge City, Kansas Signed Carl G. Tuttle Date 7-25-79 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5