

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Meade	Fraction sw¹/₄ sw ¹/₄ ne ¹/₄	Section number 27	Township number T 30 S R 27	Range number E/W
2. Distance and direction from nearest town or city: 3 miles west and 1 1/2 miles north of			3. Owner of well: Zortman and Sons			
Street address of well location if in city: Fowler, Kansas			R.R. or street: RFD			
			City, state, zip code: Fowler, Kansas 67844			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 12 1/2 in. Completion date 4-27-77 Well depth 270 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Surface		0	3	9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 14 lbs./ft. Dia. 8 5/8 in. to 270 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 7 gage		
Brown and green clay		3	145	10. Screen: Manufacturer's name W. A. Brown Type steel Dia. 8 5/8 Slot/gauze 1 1/2 " Length 60 " Set between 210 ft. and 270 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/8 "		
Fine sand		145	180	11. Static water level: 98 ft. below land surface Date 4-27-77 mo./day/yr.		
Brown sandy clay and clay layers		180	210	12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.		
Half medium sand and fine gravel		210	220	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.		
Sandy blue and brown clay		220	248	14. Well head completion: NC <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
medium sand and fine gravel		248	255	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.		
Caleche clay		255	265	16. Nearest source of possible contamination: ft. 300 Direction south type cow lot Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Half clay and Half medium sand		265	270	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hodde Drilling Co. 302 Business name License No. RR 1 Dodge City Kan Address Willie Hodde Jr. Date 4-28-77 Signed Willie Hodde Jr. Authorized representative		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

30 270 272 S 005 W 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5