

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Meade</b>	Fraction <b>NW</b> Near center of $\frac{1}{4}$ $\frac{1}{4}$ $\frac{1}{4}$ $\frac{1}{4}$	Section number <b>33</b>	Township number <b>30</b> T S R	Range number <b>27</b> E W	
2. Distance and direction from nearest town or city: <b>4-3/4 west and 3/4 north of Fowler, Ks</b> Street address of well location if in city:			3. Owner of well: <b>Lucile Congdon</b> R.R. or street: <b>502 N. Broadmoor Ct.</b> City, state, zip code: <b>Wichita, Kansas 67206</b>				
4. Locate with "X" in section below:		Sketch map:					
		6. Bore hole dia. <u>28</u> in. Completion date <u>12-26-78</u> Well depth <u>370</u> ft. 7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary 8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material <u>metal</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>31.66</u> lbs./ft. Dia. <u>16</u> in. to <u>370</u> ft. depth Wall Thickness: inches or Dia. <u>16</u> in. to <u>370</u> ft. depth gage No. <u>.188 &amp; .204</u>					
5. Type and color of material		From	To	10. Screens: Manufacturer's name <b>W.A. Brown and Cook</b>			
Surface		0	3	Type <u>17% Free-flow</u> 100 slot cook <u>16</u>			
<del>Brown-blue &amp; green clay</del>		3	114	Slot/gauze <u>1/8</u> Length <u>240</u>			
Green clay with rock stringers		114	125	Set between <u>126</u> ft. and <u>366</u> ft.			
Good med. sand and fine gravel		125	135	Cook <u>346</u> ft. and <u>366</u> ft.			
Brown clay		135	150	Gravel pack? <u>yes</u> Size range of material <u>1/2 with #1</u>			
Fine sand with 20% clay mixed		150	157	11. Static water level: _____ mo./day/yr.			
<del>Brown coleche clay</del>		157	190	<u>2</u> ft. below land surface Date <u>1-10-79</u>			
Fine sand with 40% clay		190	197	12. Pumping level below land surfaces:			
Brown clay		197	211	<u>200</u> ft. after <u>3</u> hrs. pumping <u>700</u> g.p.m.			
Fine brown sand		211	216	<u>255</u> ft. after <u>3</u> hrs. pumping <u>1400</u> g.p.m.			
Coleche brown clay		216	237	Estimated maximum yield <u>1500</u> g.p.m.			
Med. sand and gravel		237	240	13. Water sample submitted: _____ mo./day/yr.			
Coleche clay		240	251	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____			
A-1 med. sand and gravel		251	264	14. Well head completion:			
Coleche clay		264	274	<input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade			
Good med. sand and fine gravel		274	280	15. Well grouted? <u>yes</u>			
Coleche clay		280	309	With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete			
Fine brown sand		309	325	Depth: From <u>0</u> ft. to <u>10</u> ft.			
Sandy coleche clay		325	335	16. Nearest source of possible contamination:			
Fine sand with 20% clay mixed		335	345	ft. <u>200</u> Direction <u>west</u> Type <u>creek</u>			
Good half med. sand and fine gravel		345	365	Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Yellow clay		365	368	17. Pump: _____ Not installed			
Shale		368	375	Manufacturer's name <u>Peerless</u>			
				Model number <u>5 stg. ELS</u> HP <u>100</u> Volts _____			
				Length of drop pipe <u>260</u> ft. capacity <u>800</u> g.p.m.			
				Type:			
				<input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine			
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating			
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
				(Use a second sheet if needed)			
18. Elevation:	19. Remarks:		20. Water well contractor's certification:				
Topography:			This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.				
<input type="checkbox"/> Hill			<b>Ace-Hi International</b> 190				
<input type="checkbox"/> Slope			Business name _____ License No. _____				
<input type="checkbox"/> Upland			Address <u>Box 1442, Dodge City, Ks</u>				
<input checked="" type="checkbox"/> Valley			Signed <u>Carl Gotz</u> Date <u>1-25-79</u>				
				Authorized representative			

30 270 33 1/4 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5