


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Meade	Fraction NW 1/4NW 1/4 SW 1/4	Section number 36	Township number T 30 S R 27 E	Range number 27 E
2. Distance and direction from nearest town or city: 2 mi. west-1/2 north of Fowler Street address of well location if in city:			3. Owner of well: Zorthman & Sons R.R. or street: Fowler, Kansas City, state, zip code:		
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. <u>28</u> in. Completion date _____ Well depth <u>217</u> ft. 6-20-77		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
From To			9. Casing: Material <u>Metal</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>31.66</u> lbs./ft. Dia. <u>16</u> in. to <u>217</u> ft. depth Wall Thickness inches or Dia. _____ in. to _____ ft. depth gage No. <u>178</u>		
			10. Screen: Manufacturer's name <u>COOK & W.A. Brown Free-flo</u> Type <u>17% & 35%</u> Dia. <u>16</u> Slot/gauze <u>178</u> Length <u>137</u> Set between <u>25</u> ft. and <u>32</u> ft. <u>77</u> ft. and <u>207</u> ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material <u>3/8CMA</u>		
Surface			11. Static water level: _____ mo./day/yr. <u>9</u> ft. below land surface Date <u>2-16-77</u>		
Brown and green clay			12. Pumping level below land surfaces: <u>200</u> ft. after <u>5</u> hrs. pumping <u>500</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
Fine to half med. sand			13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Blue clay			14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> _____ inches above grade		
Fine to half med. sand			15. Well grouted? <u>no</u> With: _____ Neat cement _____ Bentonite _____ Concrete Depth: From _____ ft. to _____ ft.		
Blue, brown and green clay			16. Nearest source of possible contamination: <u>Field</u> ft. _____ Direction _____ Type <u>F#1#1#</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
A-1 loose med. sand and gravel			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sandy brown clay			(Use a second sheet if needed)		
Half med. sand and gravel					
Sandy brown clay			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Ace-Hi International</u> 190 Business name _____ License No. _____ Address <u>Dodge City, Ks</u> Signed <u>Carle Jittel</u> Date <u>6-24-77</u> Authorized representative		
Brown clay with 35% fine sand			18. Elevation: _____		
Sandy brown clay			19. Remarks: <u>10' of groute and pump slab to be installed by the customer-he knows this is a regulation</u> <i>Zorthman & Sons</i> <i>Carle Jittel</i>		
Brown clay with 35% fine sand			21. Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		

30 27 36
R
Sec
1/4 1/4 1/4