


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Meade	Fraction NW 1/4 NW 1/4 NE 1/4	Section number 13	Township number T 30 S R 28 E 1/4	Range number
2. Distance and direction from nearest town or city: 10 1/2 N & 1/2 E of Meade Street address of well location if in city:			3. Owner of well: Frank Wetmore R.R. or street: City, state, zip code: Meade, KS 67864		
4. Locate with "X" in section below: N  W E S 1 Mile			6. Bore hole dia. <u>26</u> in. Completion date _____ Well depth <u>373</u> ft. <u>3-7-77</u>		
5. Type and color of material See attachment			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <u>Steel</u> Height: <u>Above</u> or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP _____ PVC _____ Weight <u>36</u> lbs./ft. Dia. <u>16</u> in. to <u>373</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>219</u>		
			10. Screen: Manufacturer's name <u>Brown</u> Type <u>Louvered</u> Dia. <u>16"</u> Slot/gauze <u>.125</u> Length <u>140</u> Set between <u>233</u> ft. and <u>373</u> ft. _____ ft. and _____ ft. Gravel pack? <u>Yes</u> size range of material <u>1/4 x 1/8</u>		
			11. Static water level: _____ mo./day/yr. <u>71</u> ft. below land surface Date <u>3-8-77</u>		
			12. Pumping level below land surfaces: <u>94</u> ft. after _____ hrs. pumping <u>1451</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
			14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade		
			15. Well grouted? <u>Yes</u> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite _____ Concrete _____ Depth: From <u>0</u> ft. to <u>10</u> ft.		
			16. Nearest source of possible contamination: <u>None observed</u> ft. _____ Direction _____ Type _____ Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible _____ Turbine _____ <input type="checkbox"/> Jet _____ Reciprocating _____ <input type="checkbox"/> Centrifugal _____ Other _____					
(Use a second sheet if needed)					
18. Elevation: Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drlg. & Supply 145 Business name License No. _____ Address Box 639 Garden City, KS Signed <u>C. L. Botz</u> -17- Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Frank Wetmore DATE 2-4-77
 STREET ADDRESS _____ TEST # 3 E. LOG Yes
 CITY & STATE Meade, KS DRILLER Lee
 COUNTY Meade QUARTER NE SECTION 13 TOWNSHIP 30 RANGE 28
 LOCATION 50' N of Test #2

WELL LOCATION

Static Water Level _____
 Proposed Well Depth _____

%	FOOTAGE			DESCRIPTION OF STRATA	WELL LOCATION	
	From	Pay	To		Static Water Level	Proposed Well Depth
	0		3	Top soil		
	3		15	Brown clay, sand st.		
	15		26	Sand fine med. coarse, small to few med. gravel, a little loose, used some water, had mud heavy		
	26		56	Brown and gray color clay, sand st.		
	56		70	Brown and tan clay, hard ledges		
	70		81	Sand fine med. coarse, ledges, a yellow color sand		
	81		84	Yellow clay, sand st.		
	84		100	Sand fine med., loose, yellow clay st.		
	100		129	Sand fine, loose in places, used water, hard to catch sample, mud very heavy		
	129		145	Blue and gray and very hard ledges, used pull down a lot, used water		
	145		150	Fine sand		
	150		160	Yellow clay, a lot of sand st.		
65	160	24	184	Sand fine med. coarse, small to med. gravel, few large, used some water		
	184		189	Brown clay and ledges		
60	189	35	224	Sand fine med. coarse, small gravel, very few med., very few clay st.		
	224		228	Brown clay		
60	228	57	285	Sand fine med. coarse, small gravel, very few med., few lime rock, very few clay st.		
45	285	10	295	Sand fine med. coarse, small gravel, very few med., few lime rock, very few clay st.		
	295		298	Brown, gray, and yellow clay		
50	298	17	315	Sand fine med. coarse, few small gravel, very few clay st.		
	315		324	Brown and gray clay, a little sticky		
60	324	47	371	Sand fine med. coarse and small gravel, very little clay, used some water, very loose in places		
	371		380	Clay and lime rock		
		190				
				TOTAL DEPTH OF WELL 373'		
				Set up S; dig pit on W		

GARDEN CITY, KS
 Phone 276-3278

HENKLE DRILLING & SUPPLY CO., INC.
 IRRIGATION HEADQUARTERS

SUBLETTE, KS
 Phone 675-4311

TEST HOLES * * * * * IRRIGATION & INDUSTRIAL WELLS * * * * * STOCK WELLS