

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Meade</b>	Fraction <b>SW 1/4 SW 1/4 NE 1/4</b>	Section number <b>35</b>	Township number <b>T 30 S R 28 E/W</b>	Range number <b>28</b>
2. Distance and direction from nearest town or city: <b>7 mi north-1/2 west of Meade</b>				3. Owner of well: <b>Eddie or Bill Kobs</b> R.R. or street: <b>Meade, Kansas</b> City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>28</u> in. Completion date <u>7-30-76</u> Well depth <u>384</u> ft.		
		384		7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Surface		0	3	9. Casing: Material <u>metal</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>10</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>31.66</u> lbs./ft. Dia. <u>1 1/2</u> in. to <u>384</u> ft. depth; Wall Thickness: inches or Dia. <u>1 1/2</u> in. to <u>384</u> ft. depth; gage No. <u>188</u>		
Brown clay		3	25	10. Screen: Manufacturer's name <u>W.A. Brown</u> Type <u>10% Free-flt</u> Dia. <u>1 1/2</u> Slot/gauze <u>1/8</u> Length <u>280</u> Set between <u>104</u> ft. and <u>384</u> ft. <u>104</u> ft. and <u>384</u> ft.		
Coleche clay and rock		25	70	Gravel pack? <u>yes</u> Size range of material <u>CMA 3/8</u> down		
Fine sand		70	101	11. Static water level: <u>120</u> ft. below land surface Date <u>7-26-76</u> mo./day/yr.		
Brown clay		101	109	12. Pumping level below land surfaces: <u>200</u> ft. after <u>2</u> hrs. pumping <u>2100</u> g.p.m. <u>    </u> ft. after <u>    </u> hrs. pumping <u>    </u> g.p.m. Estimated maximum yield <u>2500</u> g.p.m.		
Half med. sand and gravel		109	161	13. Water sample submitted: <u>    </u> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u>    </u>		
Brown clay		161	171	14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
Half med. sand and gravel		171	185	15. Well grouted? <u>No</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>    </u> ft. to <u>    </u> ft.		
Fine sand with 30% brown clay mixed		185	188	16. Nearest source of possible contamination: <u>NA</u> ft. <u>    </u> Direction <u>    </u> Type <u>    </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Med. sand		188	220	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Goulds</u> Model number <u>14JHMO</u> HP <u>200</u> Volts <u>    </u> Length of drop pipe <u>240</u> ft. capacity <u>1800</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Coleche clay		220	222	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Ace-Hi International</b> 190 1/4 N 1/4 S 1/4 E 35 SW 30 NE		
Med. sand and fine gravel		222	259	Business name <u>    </u> License No. <u>    </u> Address <u>Box 1442, Dodge City, Kansas</u> Signed <u>Bill B. Tuttle</u> Date <u>8-20-76</u> Authorized representative		
Brown clay		259	267			
Med. sand and gravel		267	280			
Blue clay		280	291			
Blue clay with 35% blue sand		291	304			
Brown clay		304	318			
Brown clay with 35% sand and gravel mixed		318	326			
Brown sandy clay		326	333			
Good sand and gravel		333	344			
Brown sandy clay		344	352			
Half med. sand		352	375			
Half med. sand with 25% clay mixed		375	380			
Coleche clay and rock		380	405			
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		Top <u>10'</u> of grout and pump slab to be installed by customer-he knows this is a regulation  <i>William E. Kobs</i>		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Ace-Hi International</b> 190 1/4 N 1/4 S 1/4 E 35 SW 30 NE Business name <u>    </u> License No. <u>    </u> Address <u>Box 1442, Dodge City, Kansas</u> Signed <u>Bill B. Tuttle</u> Date <u>8-20-76</u> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5