

WATER WELL RECORD

Form WWC-5

Division of Water Resources App. No.

6412

1 LOCATION OF WATER WELL: County: MEADE		Fraction ¼ SE ¼ NE ¼ NE ¼	Section Number 2	Township No. T 30 S	Range Number R 28 <input type="checkbox"/> E <input checked="" type="checkbox"/> W
Street/Rural Address of Well Location; if unknown, distance & direction from nearest town or intersection: If at owner's address, check here <input type="checkbox"/> FROM NORTH SIDE OF MEADE- 11-1/2 M. NORTH ON HWY 23, 4,450 FT. NORTH & 135 FT. WEST			Global Positioning System (GPS) information: Latitude: (in decimal degrees) Longitude: (in decimal degrees) Elevation: Datum: <input type="checkbox"/> WGS 84, <input type="checkbox"/> NAD 83, <input type="checkbox"/> NAD 27 Collection Method: <input type="checkbox"/> GPS unit (Make/Model:) <input type="checkbox"/> Digital Map/Photo, <input type="checkbox"/> Topographic Map, <input type="checkbox"/> Land Survey Est. Accuracy: <input type="checkbox"/> <3 m, <input type="checkbox"/> 3-5 m, <input type="checkbox"/> 5-15 m, <input type="checkbox"/> >15 m		
2 WATER WELL OWNER: RR#, Street Address, Box #: BRAD BOYD 2119 18 ROAD City, State, ZIP Code : MEADE, KANSAS 67864					
3 LOCATE WELL WITH AN "X" IN SECTION BOX: <div style="text-align: center;"> </div>	4 DEPTH OF COMPLETED WELL 390 ft. Depth(s) Groundwater Encountered (1)..... ft. (2)..... ft. (3)..... ft. WELL'S STATIC WATER LEVEL..... 165 ft. below land surface measured on mo/day/yr... 11-20-10 Pump test data: Well water was..... ft. after..... hours pumping..... gpm EST. YIELD..... gpm. Well water was..... ft. after..... hours pumping..... gpm Bore Hole Diameter 30 in. to 390 ft., and in. to ft. WELL WATER TO BE USED AS: <input type="checkbox"/> Public water supply <input type="checkbox"/> Geothermal <input type="checkbox"/> Injection well <input type="checkbox"/> Domestic <input type="checkbox"/> Feedlot <input type="checkbox"/> Oil field water supply <input type="checkbox"/> Dewatering <input type="checkbox"/> Other (Specify below) <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Industrial <input type="checkbox"/> Domestic-lawn & garden <input type="checkbox"/> Monitoring well Was a chemical/bacteriological sample submitted to Department? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If yes, mo/day/yr sample was submitted..... Water well disinfected? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No				
	5 TYPE OF CASING USED: <input checked="" type="checkbox"/> Steel <input type="checkbox"/> PVC <input type="checkbox"/> Other CASING JOINTS: <input type="checkbox"/> Glued <input type="checkbox"/> Clamped <input checked="" type="checkbox"/> Welded <input type="checkbox"/> Threaded Casing diameter ... 16 in. to 200 ft., Diameter in. to ft., Diameter in. to ft. Casing height above land surface... 12 in., Weight 42.05 lbs./ft., Wall thickness or gauge No. ... 250 TYPE OF SCREEN OR PERFORATION MATERIAL: <input checked="" type="checkbox"/> Steel <input type="checkbox"/> Stainless Steel <input type="checkbox"/> PVC <input type="checkbox"/> Other (Specify) <input type="checkbox"/> Brass <input type="checkbox"/> Galvanized Steel <input type="checkbox"/> None used (open hole) SCREEN OR PERFORATION OPENINGS ARE: <input type="checkbox"/> Continuous slot <input checked="" type="checkbox"/> Mill slot <input type="checkbox"/> Gauze wrapped <input type="checkbox"/> Torch cut <input type="checkbox"/> Drilled holes <input type="checkbox"/> None (open hole) <input type="checkbox"/> Louvered shutter <input type="checkbox"/> Key punched <input checked="" type="checkbox"/> Wire wrapped <input type="checkbox"/> Saw cut <input type="checkbox"/> Other (specify) SCREEN-PERFORATED INTERVALS: From... 200 ft. to 390 ft., From ft. to ft. From..... ft. to ft., From ft. to ft. GRAVEL PACK INTERVALS: From... 20 ft. to 390 ft., From ft. to ft. From..... ft. to ft., From ft. to ft.				
6 GROUT MATERIAL: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Cement grout <input type="checkbox"/> Bentonite <input type="checkbox"/> Other Grout Intervals: From ... 0 ft. to 20 ft., From ft. to ft., From ft. to ft. What is the nearest source of possible contamination: <input type="checkbox"/> Septic tank <input type="checkbox"/> Lateral lines <input type="checkbox"/> Pit privy <input type="checkbox"/> Livestock pens <input type="checkbox"/> Insecticide storage <input type="checkbox"/> Other (specify below) <input type="checkbox"/> Sewer lines <input type="checkbox"/> Cesspool <input type="checkbox"/> Sewage lagoon <input type="checkbox"/> Fuel storage <input type="checkbox"/> Abandoned water well <input type="checkbox"/> Watertight sewer lines <input type="checkbox"/> Seepage pit <input type="checkbox"/> Feedyard <input type="checkbox"/> Fertilizer storage <input type="checkbox"/> Oil well/gas well N/A Direction from well Distance from well					
FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHO. LOG (cont.) or PLUGGING INTERVALS
		SEE ATTACHED LOG			
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was <input checked="" type="checkbox"/> constructed, <input type="checkbox"/> reconstructed, or <input type="checkbox"/> plugged under my jurisdiction and was completed on (mo/day/year) ... 11-29-10 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 208 This Water Well Record was completed on (mo/day/year) ... 11-30-10 under the business name of MINTER-WILSON DRILLING CO., INC. by (signature) : <i>Nora Keller</i>					
INSTRUCTIONS: Use typewriter or ball point pen. <i>PLEASE PRESS FIRMLY</i> and <i>PRINT</i> clearly. Please fill in blanks and check the correct answers. Send three copies (white, blue, pink) to Kansas Department of Health and Environment, Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka, Kansas 66612-1367. Telephone 785-296-5522. Send one copy to WATER WELL OWNER and retain one for your records. Include fee of \$5.00 for each constructed well. Visit us at http://www.kdheks.gov/waterwell/index.html .					

NAME BRAD BOYD
COUNTY MEADE
DATE 4-30-10

LOCATION: NE 1/4 2-30-28

STATIC WATER LEVEL -

TEST # 1-10

0' TO 6' - SURFACE TOP SOIL BROWN CLAY
6' TO 80' - BROWN, GRAY & WHITE SANDY CLAY & CLAY
80' TO 160' - SAND WITH COARSE SAND & GRAVEL STRIPS
160' TO 180' - FINE TO MEDIUM FAIRLY LOOSE SAND WITH COARSE SAND
& SMALL GRAVEL STRIPS
180' TO 220' - MEDIUM TO COARSE FAIRLY LOOSE SAND WITH GRAVEL
220' TO 240' - MEDIUM TO COARSE FAIRLY LOOSE SAND WITH BIG GRAVEL
240' TO 260' - MEDIUM TO COARSE FAIRLY LOOSE SAND
WITH GRAVEL & LITTLE CLAY MIX
260' TO 280' - FINE FAIRLY LOOSE SAND WITH CLAY MIX & SANDY CLAY STRIPS
280' TO 300' - FINE FAIRLY LOOSE SAND WITH COARSE SAND STRIPS
& CLAY MIX & BROKEN ROCK STRIP
300' TO 320' - BROKEN ROCK WITH FINE SAND & CLAY MIX
& SANDY CLAY STRIPS
320' TO 360' - FINE FAIRLY LOOSE SAND WITH CLAY MIX & SANDY CLAY STRIPS
360' TO 380' - FINE FAIRLY LOOSE SAND WITH CLAY MIX TO BROWN &
GRAY SANDY CLAY
380' TO 400' - GRAY CLAY & SHALE