


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County <u>Meade</u>	Fraction <u>NW 1/4 SE 1/4 SE 1/4</u>	Section number <u>5</u>	Township number <u>T 30 S R 29</u>	Range number <u>29</u>	<input checked="" type="checkbox"/> W				
2. Distance and direction from nearest town or city: <u>3 West, 8 South</u> Street address of well location if in city: <u>of Montezuma, Ks.</u>				3. Owner of well: <u>Chester Rexford</u> R.R. or street: City, state, zip code: <u>Montezuma, Ks.</u>							
4. Locate with "X" in section below: N W E S 1 Mile				Sketch map: 				6. Bore hole dia. <u>26</u> in. Completion date <u>9-30-75</u> Well depth <u>395</u> ft.			
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary							
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other							
				9. Casing: Material <u>Steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>72</u> in. RMP <u>16</u> <u>PVC</u> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>396</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u> </u>							
				10. Screen: Manufacturer's name <u>Johnson Division</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauge <u> </u> Length <u>20"</u> Set between <u>280-290</u> ft. and <u>350-360</u> ft. Perf. <u>200-290</u> ft. and <u>290-350-360-395</u> Gravel pack? <u>YES</u> Size range of material <u>24" Down</u>							
				11. Static water level: <u>170</u> ft. below land surface Date <u>9-17-75</u> mo./day/yr.							
				12. Pumping level below land surfaces: <u>176</u> ft. after <u>2</u> hrs. pumping <u>844</u> g.p.m. <u>181</u> ft. after <u>4</u> hrs. pumping <u>1360</u> g.p.m. Estimated maximum yield <u>1350</u> g.p.m.							
				13. Water sample submitted: <u> </u> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u> </u>							
				14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade							
				15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neop cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u> </u> ft. to <u>10</u> ft.							
				16. Nearest source of possible contamination: <u>N/A</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No							
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Goulds-US Pumps</u> Model number <u>2139</u> HP <u>125</u> Volts <u> </u> Length of drop pipe <u>280</u> ft. capacity <u>1350</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other											
(Use a second sheet if needed)											
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Winter-Wilson Drilling 208</u> Business name <u>F.O.B. A. Sander City, Ks.</u> License No. <u> </u> Address <u> </u> Signed <u> </u> Date <u>9/30/75</u> Authorized representative							

301 295 5 1/4 1/4 NUSSE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Chester Rexford
Meade County
8-30-75

Location: SE 5-30-29 1 1/4 miles North of Chet house, 30 ft.
east

Test # 1

0	3	Top Soil
3	50	Brown Sandy Clay
50	90	Fine Sand (Tight)
90	98	Fine to Med. Sand
98	277	Fine to Med. Sand & Gravel (Loose)
277	279	Gray Clay
279	290	Med. To Coarse Sand & Gravel (Loose)
290	311	Fine to Med. Sand & Gravel (Loose)
311	314	Blue Clay
314	320	Fine to Med. Sand & Gravel (Loose)
320	322	Brown Clay
322	328	Fine to Med. Sand & Gravel (Loose)
328	331	White Clay (Hard)
331	362	Fine to Med. Sand & Gravel (Loose)
362	368	White & Gray Clay
368	395	Fine to Med. Sand & Gravel, Small Streaks of white Clay
395	408	Brown, White, Gray Sandy Clay
408	427	Brown, & White Clay Streaks Fine to Med. Sand & Gravel (30%)
427	455	Brown & Gray Clay (Tight)
455	470	Fine Sand mixed with Clay (Tight)

T.D. 395'