


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Meade County	Fraction 1/4 1/4 NW 1/4	Section number 6	Township number T 30 S R 29 E/W 0	Range number
2. Distance and direction from nearest town or city: 3 mile West of Montezuma, 8 South, 2 West Street address of well location if in city:			3. Owner of well: Taylor Boyd (Clyde Poppy, tenant) R.R. or street: Montezuma, KS 67867 City, state, zip code:		
4. Locate with "X" in section below: N  S 1 Mile			Sketch map:		
5. Type and color of material			From	To	6. Bore hole dia. 26 in. Completion date 12-19-77 Well depth 423 ft.
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
					9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 423 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219
					10. Screen: Manufacturer's name Johnson Type Johnson Galv. 100-16" Slot/gauze 0-220 Plain Dia. 220-340 Perf. Set between 340-350 ft. Screen 350-400 Perf. 400-410 Screen 410-423 Perf. ft. Gravel pack? yes Size range of material 1/2 to 5/8
					11. Static water level: <input type="checkbox"/> mo./day/yr. 183 ft. below land surface Date 12-1-77
					12. Pumping level below land surfaces: 198 ft. after 2 hrs. pumping 1000 g.p.m. 208 ft. after 4 hrs. pumping 1650 g.p.m. Estimated maximum yield 1650 g.p.m.
					13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____ mo./day/yr.
					14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> 1 ft inches above grade
					15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: ft. _____ Direction N/A Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Gould 3 stg. 14 JHC Model number 154092 HP 200 Volts Rand. Length of drop pipe 260 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drlg. Co. 208 Business name License No. _____ Address Box A, Garden City, KS 67846 Signed [Signature] Date 12-21-77 Authorized representative		

77
 Perf.
 26
 39
 Sec
 10
 1/4
 1/4
 C/W

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

MINTOP-WILSON DRILLING CO.

(INCORPORATED)

1000
1000
1000

Box A

CLYDE POPPEY

MEADE COUNTY

5-10-77

Location: NW 6-20-39 3 miles west of Montezuma 8
south 2 west

Static Water Level- 175'

Test #1

0	5	Top soil
5	22	Brown sandy clay
22	66	Brown clay
66	91	Fine to med. sand and gravel
91	112	Brown clay
112	206	Fine to med. sand and gravel
206	212	Brown clay
212	231	Fine to med. sand and gravel 10% clay
231	246	Fine to med. sand and gravel
246	276	Brown and blue clay
276	366	Fine to med. sand and gravel
366	380	Brown sandy clay
380	423	Fine to med. sand and gravel
423	500	Brown sandy clay

T.D. 423

Screen