

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

|   |  |  |   |  |  |   |
|---|--|--|---|--|--|---|
| 1. Location of well:  |  | County<br><b>MEADE</b>   | Fraction<br><b>SE 1/4 NW 1/4 SE 1/4</b> | Section number<br><b>8</b>   | Township number<br><b>T 30 S R 29</b>  | Range number<br><b>29</b>   |
| 2. Distance and direction from nearest town or city:<br><b>From Missler 7 south 1/4 west, 1/4 north 1/4 west</b><br>Street address of well location if in city:                       |  |  |   | 3. Owner of well:<br><b>Quimby Demmitt</b><br>R.R. or street:<br><b>422 N. Park</b><br>City, state, zip code:<br><b>Meade, Ks. 67864</b>   |  |   |
| 4. Locate with "X" in section below:<br>N<br>W<br>E<br>S<br>1 Mile<br>1 Mile  |  |  |   | 6. Bore hole dia. <b>26</b> in. Completion date <b>4-30-76</b><br>Well depth <b>116</b> ft.  |  |   |
|   |  |  |   | 7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/><br><input checked="" type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary  |  |   |
|   |  |  |   | 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry<br><input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock<br><input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other |  |   |
| 5. Type and color of material   |  |  |   | From   | To   | 9. Casing: Material <b>steel</b> Height: Above or below<br>Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in.<br>RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft.<br>Dia. <b>16</b> in. to <b>117</b> ft. depth Wall Thickness: inches or<br>Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>  |
|   |  |  |   |  |  | 10. Screen: Manufacturer's name <input type="checkbox"/><br><b>No Screen</b><br>Type <input type="checkbox"/> Dia. <input type="checkbox"/><br>Slot/gauze <input type="checkbox"/> Length <input type="checkbox"/><br>Set between <input type="checkbox"/> ft. and <input type="checkbox"/> ft.<br>Perf. <b>180-116</b> ft. and <input type="checkbox"/> ft.<br>Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>1/4" Down</b>  |
|   |  |  |   |  |  | 11. Static water level: <input type="checkbox"/> mo./day/yr.<br><b>121</b> ft. below land surface Date <b>12-1-76</b>   |
|   |  |  |   |  |  | 12. Pumping level below land surfaces:<br><b>162</b> ft. after <b>2</b> hrs. pumping <b>882</b> g.p.m.<br><b>169</b> ft. after <b>4</b> hrs. pumping <b>1280</b> g.p.m.<br>Estimated maximum yield <b>1280</b> g.p.m.   |
|   |  |  |   |  |  | 13. Water sample submitted: <input type="checkbox"/> mo./day/yr.<br>Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>   |
|   |  |  |   |  |  | 14. Well head completion: <b>12</b><br><input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade   |
|   |  |  |   |  |  | 15. Well grouted? <b>yes</b><br>With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete<br>Depth: From <b>0</b> ft. to <b>10</b> ft.   |
|   |  |  |   |  |  | 16. Nearest source of possible contamination: <b>N/A</b><br>ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/><br>Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No  |
|   |  |  |   |  |  | 17. Pump: <input type="checkbox"/> Not installed<br>Manufacturer's name <input type="checkbox"/><br>Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/><br>Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m.<br>Type:<br><input type="checkbox"/> Submersible <input type="checkbox"/> Turbine<br><input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating<br><input type="checkbox"/> Centrifugal <input type="checkbox"/> Other |
| (Use a second sheet if needed)  |  |  |   |  |  |   |
| 18. Elevation:<br><br>Topography:<br><input type="checkbox"/> Hill<br><input checked="" type="checkbox"/> Slope<br><input type="checkbox"/> Upland<br><input type="checkbox"/> Valley |  | 19. Remarks:<br><b>Customer furnished old pump. Set old pump at 240'</b> |   |  | 20. Water well contractor's certification:<br>This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.<br><b>Minter Wilson Drilling 208</b><br>Business name <b>P.O. Box A Garden City, Mo.</b><br>Address <input type="checkbox"/><br>Signed <b>Minter Wilson</b> Date <b>8-19-76</b><br>Authorized representative |   |

30  
29  
8  
SENUSE  
1/4 1/4 1/4  
Sec

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5



# MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Quimby Dimmit

Meade County

9-24-75

SEA 8-30-29

Static Water 140

Location:  $\frac{1}{2}$  Mile south,  $\frac{1}{2}$  Mile west of his house

Test #1

|     |     |  |
|-----|-----|--|
| 0   | 2   | Top soil   |
| 2   | 5   | Brown clay   |
| 5   | 33  | Brown sandy clay   |
| 33  | 47  | Brown sandy clay mixed with white clay & rock<br>(tight) |
| 47  | 79  | Fine to med sand & gravel (loose)                        |
| 79  | 143 | Brown sandy clay mixed with white clay                   |
| 143 | 391 | Fine to med sand & gravel (loose)                        |
| 391 | 400 | Fine to med sand & gravel (tight)                        |
| 400 | 446 | Fine to med sand & gravel (loose)                        |
| 446 | 455 | Grey yellow brown clay (tight)                           |

TD 446'