

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Meade	Fraction NE 1/4 SW 1/4 NE 1/4	Section number 9	Township number T 30 S R	Range number 29 (NW)
2. Distance and direction from nearest town or city: 3 west 8 1/2 south 1 1/2 east of Montezuma, Street address of well Location if in city:				3. Owner of well: Chester Rexford R.R. or street: Meade, KS 67864 City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>26</u> in. Completion date <u>12-1-76</u> Well depth <u>360</u> ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From		To		9. Casing: Material <u>steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lb./ft. Dia. <u>16</u> in. to <u>361</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u> </u>
						10. Screenshot: Manufacturer's name Johnson Screen Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauze <u> </u> Length <u>20'</u> Set between <u>320</u> ft. and <u>340</u> ft. Perf. <u>240-320</u> ft. and <u>340-360</u> ft. Gravel pack? <input type="checkbox"/> Size range of material <u> </u> <input checked="" type="checkbox"/> Down
						11. Static water level: <u>163</u> ft. below land surface Date <u>11-23-76</u> <u>173</u> ft. after <u>2</u> hrs. pumping <u>825</u> g.p.m. <u>178</u> ft. after <u>4</u> hrs. pumping <u>1400</u> g.p.m. Estimated maximum yield <u>1400</u> g.p.m.
						12. Pumping level below land surfaces: <u>173</u> ft. after <u>2</u> hrs. pumping <u>825</u> g.p.m. <u>178</u> ft. after <u>4</u> hrs. pumping <u>1400</u> g.p.m. Estimated maximum yield <u>1400</u> g.p.m.
						13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>
						14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade
						15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
						16. Nearest source of possible contamination: <u>n/a Field</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
						17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Goulds US Pump</u> Model number <u>14JHC</u> HP <u> </u> Volts <u> </u> Length of drop pipe <u>260</u> ft. capacity <u>1000</u> . Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling <u>208</u> Business name License No. Address <u>P.O. Box 4 Garden City, KS</u> Signature <u>[Signature]</u> Date <u>2-24-77</u> Authorized representative
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: We did not install the gearhead					

30 29 9 NE SW NE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

CHESTER REXFORD
MEADE COUNTY
11-8-76

Location: NE 9-30-29 Center of west side 3/4 mile north
of house 1/2 east
Static Water Level-

Test #4

0	1	Top soil
1	44	Brown clay
44	80	Brown clay and fine sand
80	107	Brown clay
107	359	Fine to med. sand and gravel Loose
359	365	Brown clay
365	386	Blue clay
386	395	Fine to med. sand and gravel 15% clay Loose
395	410	Brown clay and white rock tight

T.W. 360