


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>MEADE</b>	Township name	Fraction <b>SW 1/4 NE 1/4</b>	Section number <b>14</b>	Town number <b>30</b>	Range number <b>29 E</b>
Distance and direction from nearest town or city: <b>South of Copeland to 2nd Curve 2 South 7 East 1/4 South 1/4 East</b> Street address of well location if in city:				Owner of well: <b>Otis Elliott</b> Address: <b>Montezuma, Ks. 67867</b>		
Locate with "X" in section below: N  W E S 1 Mile				Sketch map:		4 Well depth: <b>26</b> ft. Date of completion <b>2-29-76</b> Well diameter <b>3.90</b> in.
2 Type and color of material				From		To
				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
				7 Casing: Material <b>Steel</b> Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <b>12</b> in. Digm. <b>16</b> in. to <b>391</b> ft. depth! Weight <b>36.87</b> lb./ft. — Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No		
				8 Screen: <b>Johnson Division</b> Manufacturer <b>Johnson Division</b> Type <b>Galv.</b> Dia. <b>16"</b> Slot/gauze _____ Length <b>20'</b> Set between <b>330-350</b> ft. Fittings <b>Perf 180-330 350-390</b> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <b>1/2"</b>		
				9 Static water level: <b>127</b> ft. below land surface Date <b>12-19-75</b>		
				10 Pumping level below land surfaces: <b>112</b> ft. after <b>3</b> hrs. pumping <b>1120</b> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <b>1100</b> g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				12 Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> ft <input type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From _____ ft. to <b>10</b> ft.		
				14 Nearest source of possible contamination: <b>N/A</b> ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Peerless-PMC</b> Model number <b>5746</b> HP <b>125</b> Volts _____ Length of drop pipe <b>220</b> ft. capacity <b>1100</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Winter-Wilson Drilling</b> Business name <b>J.O.B. A Garden City</b> License No. _____ Address _____ Signature <b>[Signature]</b> Date <b>3-2-76</b> Authorized representative		

Down 30 29 W 14 S W 1/4

Profess

als

# WINTER-WILSON DRILLING CO.

INCORPORATED

and Domestic  
Water Systems  
and Repairing

Phone 276-8269

P.O. Box 493

GARDEN CITY, KANSAS 67846

Otis Elliot  
Meade County  
11-1-75

Location: NW 14-30-29  
From SE Corner of Nontezuma, 11 miles South,  
2 miles West,  $\frac{1}{4}$  South,  $\frac{1}{4}$  East to pivot point

## Test # 1

0	3	Top Soil
3	17	Brown Clay
17	50	Fine to Med. Sand
50	77	Fine to Med. Sand & Gravel (Tight)
77	80	Brown Sandy Clay
80	285	Fine to Med. Sand & Gravel (Loose)
285	288	Hard Streaks
288	352	Fine to Med. Sand & Gravel (Loose)
352	390	Fine to Med. Sand & Gravel, Streaks of Clay (10%)
390	395	Gray & Brown Clay

TD 390'