


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County MEADE	Township name PIVOT SW	Fraction SW	Section number 14	Town number 30	Range number 29 E		
Distance and direction from nearest town or city: South of Copeland Ks. To Second Curve, 2 South, 5 East 1 South			3 Owner of well: Otis Elliott					
Street address of well location if in city: 2 East 1/4 North 1/4 East			Address: Montezuma, Ks 67867					
Locate with "X" in section below: N  W E S 1 Mile			Sketch map:			4 Well depth: 26 ft. Date of completion 2-29-76 Well diameter 360 in.		
2 Type and color of material			From To			5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
						6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
						7 Casing: Material Steel Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. _____ Weight 36.87 lbs./ft. _____ 16 in. to 361 ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No _____ in. to _____ ft. depth		
						8 Screen: Johnson Division Manufacturer Galv. Dia. 16" Type _____ Length 20' Slot/gauze _____ Length 310-350 Set between 300-310 and 310-350 Fittings Perf. 180-300 310-340, 350-360 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material all Down		
						9 196 water level: 12-20-75 _____ ft. below land surface Date _____		
						10 Pumping level below land surfaces: 1227 15h _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1200 g.p.m.		
						11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
						12 Well head completion: <input type="checkbox"/> Pitless adapter 12" <input type="checkbox"/> Inches above grade		
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 10 ft.		
						14 Nearest source of possible contamination: N/A ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
15 Pump: <input type="checkbox"/> Not installed Peerless GMC Manufacturer's name _____ Model number 7545 HP 125 Volts _____ Length of drop pipe 220 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other								
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling 208 Business name P.O.B. A Garden City, Ks Address _____ Signed <i>[Signature]</i> Date 6-30-76 Authorized representative					

30 29 14
C 2014

Professional

WINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Otis Elliot
Meade County
11-3-75

Location: SW 14-30-29
½ mile South of Test # 1 on pivot point

Test # 2

0	3	Top Soil
3	20	Brown Sandy Clay
20	42	Fine to Med. Sand, Streaks of Clay (10%)
42	51	Fine to Med. Sand
51	72	Fine to Med. Sand & Gravel (Loose)
72	89	Brown Sandy Clay
89	312	Fine to Med. Sand & Gravel (Loose)
312	330	Fine to Med. Sand & Gravel (Little Tight)
330	360	Fine to Med. Sand & Gravel (Loose)
360	380	Fine Sand mixed with White & Brown Clay

TD 360'