


USE TYPEWRITER OR CALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>Meade</b>	Fraction <b>SW 1/4 NE 1/4 SW 1/4</b>	Section number <b>17</b>	Township number <b>T 30 S R</b>	Range number <b>29 <sup>10</sup> EW</b>
2. Distance and direction from nearest town or city: <b>3 west 9 south</b> Street address of well location or P.M. city: <b>1 west 1 south of Montezuma</b>			3. Owner of well: <b>Chester Rexford</b> R.R. or street: <b>Meade, KS 67864</b> City, state, zip code:		
4. Locate with "X" in section below: 			Sketch map:		
5. Type and color of material			6. Bore hole dia. <u>26</u> in. Completion date <u>12-30-76</u> Well depth <u>434</u> ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <u>steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>435</u> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. <input type="checkbox"/>		
			10. Screen: Manufacturer's name <u>Johnson Screen</u> Type <u>Galv.</u> Dia. <u>20 1/2"</u> Slot/gauze <input type="checkbox"/> Length <u>380</u> ft. Set between <u>360</u> ft. and <u>380</u> ft. <b>Perf: 240-360 ft. and 380-434 ft.</b> Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/2" Down</u>		
			11. Static water level: <input type="checkbox"/> mo./day/yr. <u>180</u> ft. below land surface Date <u>11-24-76</u>		
			12. Pumping level below land surfaces: <u>194</u> after <u>2</u> hrs. pumping <u>850</u> g.p.m. <u>204</u> after <u>4</u> hrs. pumping <u>1500</u> g.p.m. Estimated maximum yield <u>1500</u> g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade		
			15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <u>Eldorado</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Goulds US Pumps</u> Model number <u>14 THC</u> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <u>300</u> ft. capacity <u>1000</u> Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation:  Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:  <b>We did not install the gearhead</b>		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter Wilson Drilling 208</b> Business name License No. Address <u>P.O. Box A Garden City, KS</u> Signed <u>[Signature]</u> Date <u>3-24-77</u> Authorized representative		

30  
T  
29  
R  
17  
SW  
NE  
1/4  
1/4  
Sec

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The  
Professionals

# MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

CHESTER REXFORD

DEADE COUNTY

11-4476

Location: SW 17-30-29 from S.W. corner of  $\frac{1}{4}$  60 Ft. north  
Static Water Level-

## Test #2

0	1	Top soil
1	50	Brown clay
50	67	Brown clay and fine sand
67	80	Fine to med. sand and fine gravel loose
80	107	Fine to med. sand and gravel stks. of coarse gravel
107	116	Brown clay
116	125	Fine to med. sand and gravel loose
125	140	Fine to med. sand and gravel 20% clay Loose
140	155	Brown clay
155	162	Fine to med. sand and gravel loose
162	170	Brown clay
170	182	Fine to med. sand and gravel loose small hard stks.
182	385	Fine to med. sand and gravel loose
385	389	Fine to med. sand and gravel 15% clay and brown rock hard
389	395	Fine to med. sand and gravel loose
395	434	Fine to med. sand and gravel loose small hard stks.
434	462	Brown clay and white rock tight hard stks.
462	475	Brown clay and white rock small stks. of fine sand
475	485	Brown clay and white rock hard

T.D.434