

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Meade	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 22	Township number T 30 S R 29	Range number 29	X/W
2. Distance and direction from nearest town or city: Street address of well location if in city:			7 North of Collard 1 East		3. Owner of well: R.R. or street: City, state, zip code:		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		6. Bore hole dia. 9 7/8 in. Completion date _____ Well depth 348 ft. 3-05-76		
5. Type and color of material			From	To	7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Top soil			0	5	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay			5	14	9. Casing: Material PVC Height: Above or below Threaded _____ Welded _____ Surface 24 in. RMP _____ PVC _____ Weight 291 lbs./ft. 100 Dia. 5 in. to 348 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth page No. 265		
Med. to lar. sand			14	230	10. Screen: Manufacturer's name _____ Jess & Lowell Type PVC Dia. 5" Slot/gauze 1/8" Length 50' Set between 218 ft. and 348 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 3/16"		
Yellow clay & Med. to lar. sand & gravel			230	352	11. Static water level: _____ mo./day/yr. 136 ft. below land surface Date 2/26/76		
					12. Pumping level below land surfaces: N/A _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
					13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
					14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 Inches above grade		
					15. Well grouted? Yes With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.		
					16. Nearest source of possible contamination: none ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
					17. Pump: _____ Not installed Manufacturer's name Aermotor Model number SD19 HP 2 Volts 220 Length of drop pipe 210 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other		
			(Use a second sheet if needed)				
18. Elevation:		19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Friesen Windmill 252 Business name License No. Address Meade, Kansas 67864 Signed <i>John J. Friesen</i> Date 2-17-76 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley							

T 30
 R 29
 S 22
 Sec 22
 SW 1/4 SW 1/4 SW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5