

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>SUMNER</b>	Fraction <b>1/4 NW 1/4 SW 1/4</b>	Section number <b>11</b>	Township number <b>T 30 S</b>	Range number <b>R 3W E/W</b>
2. Distance and direction from nearest town or city: Street address of well location if in city: <b>2 miles South of K-42 on Viola Road, 1 mile East, 3/4 mile South, East side</b>			3. Owner of well: <b>John Wall</b> R.R. or street: <b>Rt #1</b> City, state, zip code: <b>Viola, Kansas</b>			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: <b>of Road. Viola, Kansas</b>			
5. Type and color of material			From	To	6. Bore hole dia. <b>11</b> in. Completion date <b>9-2-78</b> Well depth <b>45</b> ft.	
Topsoil			0	3	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Clay			3	17	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Fine sand			17	28	9. Casing: Material <b>Styrene</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input checked="" type="checkbox"/> PVC Weight <input type="checkbox"/> lbs./ft. Dia. <b>5</b> in. to <b>45</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. <b>.200</b>	
Medium sand			28	45	10. Screen: Manufacturer's name <b>Sunflower plastic</b> Type <b>styrene</b> Dia. <b>5"</b> Slot/gauge <b>.06</b> Length <b>15</b> Set between <b>30</b> ft. and <b>45</b> ft. ft. and <b>1/4-1/8"</b> Gravel pack? <b>yes</b> Size range of material	
					11. Static water level: <b>15</b> ft. below land surface Date <b>9-2-78</b> mo./day/yr.	
					12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.	
					13. Water sample submitted: mo./day/yr. Yes No Date	
					14. Well head completion: <b>12</b> capped Pitless adapter inches above grade	
					15. Well grouted <b>yes 1-2 fine sand mix</b> With: Neat cement Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>40"</b> ft. to <b>14</b> ft.	
					16. Nearest source of possible contamination: ft. Direction Type <b>None</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)						
18. Elevation:  Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks:  <b>Flat ground Septic system not installed at this time No apparent source for contamination</b>		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Harp Well &amp; Pump 236</b> Business name License No. Address <b>Wichita, Kansas 67209</b> Signed <b>M. Arnold</b> Date <b>10-6-78</b> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5