


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: <u>Sumner</u>		Fraction: <u>NE 1/4 NW 1/4 NW 1/4</u>	Section number: <u>19</u>	Township number: <u>T 30 S R 3</u>	Range number: <u>E 1/4</u>
2. Distance and direction from nearest town or city: <u>3-W-3N 1/4 E</u> Street address of well location if in city: <u>Conway Springs, KS</u>			3. Owner of well: <u>William Stuhlsatz</u> R.R. or street: <u>RR</u> City, state, zip code: <u>Conway Springs Kans. 67031</u>		
4. Locate with "X" in section below: 		Sketch map: <u>New location</u>		6. Bore hole dia. <u>2 1/4</u> in. Completion date: <u>7-29-77</u> Well depth: <u>35</u> ft.	
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
<u>Top Soil</u>		<u>0</u>	<u>6</u>	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
<u>Sandy</u>		<u>6</u>	<u>19</u>	9. Casing: Material <u>PltS</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>18</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft.	
<u>Red Clay</u>		<u>19</u>	<u>35</u>	Dia. <u>6</u> in. to <u>35</u> ft. depth Wall Thickness: inches or Dia. <u>6</u> in. to <u>35</u> ft. depth gage No. <u>18</u>	
				10. Screen: Manufacturer's name <u>Sunflow Plastics</u> Type <u>RMP</u> Dia. <u>6</u> Slot/gauze <u>06 1/4</u> Length <u>10</u> Set between <u>25</u> ft. and <u>35</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/8 - 1/2</u>	
				11. Static water level: <u>10</u> ft. below land surface Date <u>7-29-77</u>	
				12. Pumping level below land surfaces: <u>Not Pumped</u> ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.	
				13. Water sample submitted: <u>no</u> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date ____	
				14. Well head completion: <u>no</u> ____ Pitless adapter ____ inches above grade	
				15. Well grouted? <u>yes</u> With: <u>Neat cement</u> <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete <input type="checkbox"/> Depth: <u>Top of well</u> ft. to <u>10</u> ft.	
				16. Nearest source of possible contamination: <u>Draw</u> ft. <u>200</u> Direction <u>S</u> Type <u>Draw</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other	
18. Elevation:		19. Remarks:		20. Water well contractor's certification:	
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		<u>Well was not grouted because they were going to dig basement then grout. He knew it is a regulation. This has been done since William Stuhlsatz</u>		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Winter Const Co</u> <u>352</u> Business name License No. Address <u>Conway Springs KS</u> Signed <u>Edgar Stuhlsatz</u> Date <u>7-30-77</u> Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5