

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: <u>Sumner</u>		County		Fraction <u>1/4 SW 1/4 NE 1/4</u>		Section number <u>33</u>		Township number <u>T 30 S R 3 E W</u>		Range number	
2. Distance and direction from nearest town or city: <u>302 Crammer</u> Street address of well location if in city: <u>Conway Springs, Kansas</u>						3. Owner of well: <u>John Scott</u> R.R. or street: <u>302 Crammer</u> City, state, zip code: <u>Conway Springs, KS</u>					
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile						Sketch map: <u>Kansas</u>					
5. Type and color of material						From		To		6. Bore hole dia. <u>75</u> in. Completion date <u>3-27-76</u> Well depth <u>75</u> ft.	
Sandy topsoil						0		2		7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Fine sand						2		35		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Medium sand						40		47		9. Casing: Material <u>STYRENE</u> Height: <u>96</u> in. Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>75</u> lbs./ft. Dia. <u>5</u> in. to <u>75</u> ft. depth Wall Thickness: inches or Dia. <u>5</u> in. to <u>75</u> ft. depth gage No. <u>1200</u>	
Red shale						47		75		10. Screen: Manufacturer's name <u>SUNFLOWER PLASTIC</u> Type <u>STYRENE</u> Dia. <u>5</u> in. Slot/gauze <u>106</u> Length <u>35</u> Set between <u>40</u> ft. and <u>75</u> ft. ft. and <u>75</u> ft. Gravel pack? <u>YES</u> Size range of material <u>1/4 - 1/8</u> "	
										11. Static water level: <u>35</u> ft. below land surface Date <u>3-27-76</u> mo./day/yr.	
										12. Pumping level below land surfaces: ft. after <u> </u> hrs. pumping <u> </u> g.p.m. ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u> </u> g.p.m.	
										13. Water sample submitted: <u> </u> mo./day/yr. Yes <input type="checkbox"/> No <input type="checkbox"/> Date <u> </u>	
										14. Well head completion: <u>12</u> Capped Pitless adapter <u> </u> inches above grade	
										15. Well grouted? <u>YES</u> With: <u> </u> Neat cement <u> </u> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>40</u> ft. to <u>14</u> ft.	
										16. Nearest source of possible contamination: <u>Sumner</u> ft. <u>60</u> Direction <u>NE</u> Type <u>Line</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
										17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:						19. Remarks: <u>Flat Ground</u>					
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>HARP WELL PUMP</u> <u>236</u> Business name <u>WICHITA, KANSAS</u> License No. <u> </u> Address <u> </u> Signed <u>M. Arnold</u> Date <u>4-17-76</u> Authorized representative					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5