

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Meade	Township name Mertilla	Fraction NE¹/₄ of SW¹/₄	Section number 11	Town number T 30 S	Range number R 30 W
Distance and direction from nearest town or city: 1/2 mile north of Copeland, Ks. Street address of well location if in city:				3 Owner of well: Phil Smith Address: Copeland, Ks.		
Locate with "X" in section below:		Sketch map:				
N						
S ← 1 Mile →						
2		Type and color of material		From	To	4 Well depth: <u>395</u> ft. Date of completion <u>4-16-75</u> Well diameter <u>26</u> in. 5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary 6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/> _____ 7 Casing: Material <u>Steel</u> Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. Digm. <u>16</u> in. Weight <u>36.87</u> lbs./ft. <u>1</u> <u>16</u> in. to <u>396</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth!
						8 Screen: Manufacturer <u>Johnson Division</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/groove _____ Length _____ Set between <u>360</u> ft. and <u>380</u> ft. _____ <u>Perforations 200-360, 380-395</u> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>1/2" down</u>
						9 Static water level: <u>173</u> ft. below land surface Date <u>4-4-75</u>
						10 Pumping level below land surfaces: <u>184</u> ft. after <u>2</u> hrs. pumping <u>784</u> g.p.m. <u>190</u> ft. after <u>4</u> hrs. pumping <u>1218</u> g.p.m. Estimated maximum yield <u>1200</u> g.p.m.
						11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
						12 Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From <u>0</u> ft. to <u>10</u> ft.
						14 Nearest source of possible contamination: <u>N/A</u> ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
						15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Peerless-FMC</u> Model number <u>4602</u> HP _____ Volts _____ Length of drop pipe <u>250</u> ft. capacity <u>800</u> g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
16 Remarks: elevation		Gearhead not put on. Topography: <u>Fair Well.</u> <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				
		17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Minter-Wilson Drilling Co. 208</u> Business name _____ License No. _____ Address <u>Box 493 Garden City, Ks.</u> Signed <u>[Signature]</u> Date <u>6-5-75</u> Authorized representative				

The Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Phil Smith

Static Water Level 168

0	160	Overburden
160	180	Sand & Gravel w/ Rock Streams
180	380	Sand & Gravel
380	395	Sand & Gravel
395	400	Gray Shale

END