

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County MEADE	Fraction NW/4 SE 1/4 NE 1/4	Section number 13	Township number T 30 S	Range number R 30 <i>EW</i>
2. Distance and direction from nearest town or city: South of Copeland Ks. to 2ND Curve 2 South 2 1/2 East 3/8 South Street address of well location if in city:				3. Owner of well: A. E. Aenchbacher R.R. or street: 432 Langford Court City, state, zip code: Wichita, Ks. 67206		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>26</u> in. Completion date <u>11-15-75</u> Well depth <u>140</u> ft.		
		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <u>Steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>14 1/2</u> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>		
5. Type and color of material				From	To	10. Screen: Manufacturer's name <u>Johnson Division</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauze <input type="checkbox"/> Length <u>20'</u> Set between <u>100-120</u> ft. and <input type="checkbox"/> ft. Perf. <u>200-400</u> ft. and <u>420-440</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/2" DOWN</u>
				11. Static water level: <u>178</u> ft. below land surface Date <input type="checkbox"/>		
				12. Pumping level below land surfaces: <u>187</u> ft. after <u>2</u> hrs. pumping <u>931</u> g.p.m. <u>193</u> ft. after <u>4</u> hrs. pumping <u>1110</u> g.p.m. Estimated maximum yield <u>1100</u> g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade		
				15. Well grouted? <u>Yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
				16. Nearest source of possible contamination: <u>1/4</u> ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Goulds US pumps</u> Model number <u>14 TIC</u> HP <u>1400</u> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Winter-Wilson Drilling</u> Business name <u>P.O. B. A Garden City, Ks</u> Address <input type="checkbox"/> Signed <u>[Signature]</u> Date <u>6-30-76</u> Authorized representative		

30 30 W
 R
 13
 Sec
 1/4 1/4
 NUS EUE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Dick Finchan
Gene Ansbacher (Owner)
Meade County
10-20-75

Location: NE 13-30-30
2½ miles West of Chester Rexfords House, ½ mile
South from ½ mile line, 200 ft. South

Test # 1

0	3	Top Soil
3	16	Brown Clay
16	69	Brown Sandy Clay
69	80	Fine to Med. Sand
80	108	Fine to Med. Sand & Gravel
108	124	Brown Sandy Clay
124	161	Fine to Med. Sand & Gravel (Loose)
161	173	Brown Sandy Clay
173	185	Fine to Med. Sand & Gravel, Streaks of Clay (10%)
185	290	Fine to Med. Sand & Gravel (Loose)
290	311	Fine to Med. Sand (Loose)
311	340	Fine to Med. Sand, Streaks of Clay (10%)
340	351	Gray & Blue Clay, Streaks of Fine to Med. Sand (20%)(Tight)
351	440	Fine to Med. Sand & Gravel (Loose)
440	455	Brown Sandy Clay, Streaks of Gray Clay

TD 440'