

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County MEADE	Fraction N¹/₄ SE ¹/₄ NW ¹/₄	Section number 13	Township number T 30 S	Range number R 30 ¹/₄ W
2. Distance and direction from nearest town or city: south of Copeland to 2nd curve 2 south 8 east ¹/₄ south			3. Owner of well: Jerry Grace R.R. or street: Meade, Ks. 67864 City, state, zip code:			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. <u>26</u> in. Completion date <u>6-30-76</u> Well depth <u>431</u> ft.	
		7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
		9. Casing: Material <u>steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.8</u> lbs./ft. Dia. <u>16</u> in. to <u>432</u> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>			10. Screen: Manufacturer's name <u>Johnson Division</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauze <u>100</u> Length <u>20'</u> Set between <u>400</u> ft. and <u>420</u> ft. Perf. <u>190-400</u> ft. and <u>420-431</u> ft. Gravel pack <u>826</u> Size range of material <u>1/2" Down</u>	
5. Type and color of material		From	To	11. Static water level: <u>182</u> ft. below land surface Date <u>6-4-76</u> 12. Pumping level below land surfaces: <u>1600</u> <u>195</u> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <u>1600</u> g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade		
				15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft. <u>N/A</u>		
				16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <u>Not installed</u> Manufacturer's name <u>Goulds US pumps</u> Model number <u>14JHC</u> HP <u>200</u> Volts <input type="checkbox"/> Length of drop pipe <u>240</u> ft. capacity <u>1200</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Minter Wilson Drilling 208</u> Business name <u>P.O. Box 4 Garden City, Ks.</u> Address <u>_____</u> Signature <u>[Signature]</u> Date <u>6-1-76</u> Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

30 30 W 13
T
R
S
Sec

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

JERRY GRACE
Meade County
2-2-76

Location No 13-30-30 From Chester Wexfords house, 3 MA.
West, 1 Mile South, East Side Of Road
Static Water Level 170'

Test #1

0	3	Top Soil
3	5	Brown Clay
5	50	Brown Sandy Clay
50	80	Brown Sandy Clay & Fine Sand Mixture (50%)
80	108	Fine To Med. Sand & Gravel (Loose)
108	140	Fine To Med. Sand & Gravel, Streaks of Clay (10%)
140	200	Fine To Med. Sand & Gravel (Loose)
200	215	Fine To Med. Sand & Gravel, Streaks Of Clay (10%)
215	276	Fine To Med. Sand & Gravel (Loose)
276	290	Blue Clay & Brown Clay
290	431	Fine To Med. Sand & Gravel (loose)
431	450	Brown Clay, Gray Clay, Small streaks Of White Rock
450	455	Gray Clay (Tight)

T.D. 431'
20' Screen