


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County MEADE	Fraction SW 1/4 NE 1/4 SW 1/4	Section number 13	Township number T 30 S R 30	Range number 30	NW
2. Distance and direction from nearest town or city: south of Copeland to 2nd curve 2 south 2 east 3/4 south				Owner of well: Jerry Grace		City, state, zip code: Meade, Ks. 67864	
4. Locate with "X" in section below: 				Sketch map:		6. Bore hole dia. 26 in. Completion date 6-30-76 Well depth 130 ft.	
5. Type and color of material				From		To	
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
				9. Casing: Material <u>steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>131</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u> </u>			
				10. Screen: Manufacturer's name <u>Johnson Division</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauze <u>100</u> Length <u>20'</u> Set between <u>400</u> ft. and <u>420</u> ft. <u>Perf.</u> <u>200-400</u> ft. and <u>420-430</u> ft. Gravel pack? <u>yes</u> Size range of material <u>1/2" Down</u>			
				11. Static water level: <u>180</u> ft. below land surface Date <u>6-4-76</u> mo./day/yr.			
				12. Pumping level below land surfaces: <u>194</u> ft. after <u>3</u> hrs. pumping <u>1550</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>1550</u> g.p.m.			
				13. Water sample submitted: <u> </u> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u> </u>			
				14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade			
				15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.			
16. Nearest source of possible contamination: ft. <u> </u> Direction <u> </u> Type <u>N/A</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No							
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Goulds US Pumps</u> Model number <u>14110</u> HP <u>200</u> Volts <u> </u> Length of drop pipe <u>220</u> ft. capacity <u>1200</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other							
(Use a second sheet if needed)							
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:						
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Minter Wilson Drilling 208</u> Business name <u>P.O. Box A Garden City, KS</u> License No. <u> </u> <u> </u> Signed <u> </u> Date <u>1-76</u> Authorized representative							

30 300' 13 SUMNER

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

JERRY GRACE
 Meade County
 2-3-76

Location Sec 13-30-30
 From Chester Saxford's House, 3 Miles West,
 3/4 Mile South, East Side Of Road

Static Water Level 170'

Test #2

0	3	Top Soil
3	5	Brown Clay
5	37	Brown Sandy Clay
50	71	Fine Sand, Streaks Of Clay (10%)
71	77	Brown Sandy Clay
80	205	Fine To Med. Sand & Gravel (Loose)
298	309	Hard Streaks
309	336	Fine To Med. Sand & Gravel (Loose)
306	2870	Fine To Med. Sand & Gravel, Streaks Of Clay (20%) Tight
321	335	Fine Sand & Blue Clay Mixture (50%) No Good
335	354	Fine To Med. Sand & Gravel, Streaks Of Clay (10%)
354	401	Fine To Med. Sand & Gravel (Loose)
400	419	Fine To Med. Sand & Gravel, Streaks Of Clay (10%)
410	430	Fine To Med. Sand & Gravel, Streaks Of Clay & White Rock (10%)
430	440	Brown White Gray Clay (Tight)