


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Meade	Township name Mertilla	Fraction SE$\frac{1}{4}$, SW$\frac{1}{4}$	Section number 13	Town number T 30 S	Range number R 30 W
Distance and direction from nearest town or city: 6 south, 2 east, 2 south, 1/2 east of Copeland, Ks. Street address of well location if in city:				3 Owner of well: Jerry Grace Address: Meade, Kansas 67864		
Locate with "X" in section below: N  W E S 1 Mile				Sketch map:		
2 Type and color of material				4 Well depth: <u>425</u> ft. Date of completion <u>4-8-75</u> Well diameter <u>26</u> in.		
				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
				7 Casing: Material <u>Steel</u> Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. Diam. <u>16</u> in. to <u>426</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u>16</u> in. to <u> </u> ft. depth		
				8 Screen: Manufacturer <u>Johnson Division</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauze <u> </u> Length <u>20'</u> Set between <u>280</u> ft. and <u>290</u> ft. <u>390-400</u> Perforations: 220-280, 290-300, 370-390, 400-425 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>2" down</u>		
				9 Static water level: <u>173</u> ft. below land surface Date <u>5-5-75</u>		
				10 Pumping level below land surfaces: <u>219</u> ft. after <u>2</u> hrs. pumping <u>752</u> g.p.m. <u>241</u> ft. after <u>4</u> hrs. pumping <u>1100</u> g.p.m. Estimated maximum yield <u>1100</u> g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>		
				12 Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> <u> </u> Depth: From <u>0</u> ft. to <u>10</u> ft.		
14 Nearest source of possible contamination: <u>N/A</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No						
15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Peerless-FMC</u> Model number <u>3771</u> HP <u> </u> Volts <u> </u> Length of drop pipe <u>240</u> ft. capacity <u>800</u> g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other						
16 Remarks: elevation Fair Well Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name License No. <u> </u> Address <u>Box #93 Garden City, Ks.</u> Signed <u>[Signature]</u> Date <u>6-5-75</u> Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WW-C-5

The
Professionals

MINER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Jerry Grace
Gray County

9-19-74

Best # 1

Location: South of Copeland, 6 Miles, 2 East, 2
South, $\frac{1}{2}$ East, South Side of the road

0	2	Top Soil
2	35	Brown clay
35	80	Brown sandy clay & brown clay
80	147	Fine to med. sand & gravel (Loose)
147	179	Brown sandy clay
179	185	Fine to med. sand & gravel (Loose)
185	202	Fine to med. sand & gravel (Small hard streaks)
202	215	Fine to med. sand & gravel fine (Loose)
215	232	Brown & gray clay
232	245	Fine to med. sand & gravel 10% clay (Loose)
245	260	Fine to med. sand & gravel (Loose)
260	274	Brown & gray clay (streaks of white rock) Hard
274	299	Fine to med. sand & gravel (Loose)
299	305	Brown clay (Streaks of white rock Hard)
305	367	Blue clay
367	380	Fine to med. sand & gravel 10% clay (Hard streaks of white rock)
380	401	Fine to med. sand & gravel (Loose)
401	425	Fine to med. sand & gravel (small hard streaks)
425	442	Brown & gray clay (hard)
442	451	Brown gray & yellow clay with white rock (Hard)
451	455	Blue clay (Hard)