


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>Meade</b>	Fraction <b>NW 1/4 SE 1/4 NW 1/4</b>	Section number <b>16</b>	Township number <b>T 30 S R 30</b>	Range number <b>30</b>
2. Distance and direction from nearest town or city: <b>7 south, 1 east,</b> Street address of well location if in city: <b>1/2 south of Copeland</b>			3. Owner of well: <b>Bud Kohart</b> R.R. or street: <b>Meade, Ks. 67864</b> City, state, zip code:		
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. <b>26</b> in. Completion date <b>2-28-77</b> Well depth <b>446</b> ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <b>Steel</b> Height: Above <del>surface</del> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia. <b>16</b> in. to <b>447</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>250</b>		
			10. Screen: Manufacturer's name <b>Johnson</b> Type <b>galv.</b> Dia. <b>16"</b> Slot/gauge <input type="checkbox"/> Length <b>10</b> ft. Set between <b>390-400</b> ft. and <b>420-430</b> ft. Perf: <b>210-390</b> ft. and <b>400-420, 430-446</b> Gravel pack? <b>Yes</b> Size range of material <b>1/2" down</b>		
			11. Static water level: <input type="checkbox"/> mo./day/yr. <b>167</b> ft. below land surface Date <b>1-22-77</b>		
			12. Pumping level below land surfaces: <b>186</b> ft. after <b>2</b> hrs. pumping <b>900</b> g.p.m. <b>198</b> ft. after <b>4</b> hrs. pumping <b>1450</b> g.p.m. Estimated maximum yield <b>1450</b> g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
			14. Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> Inches above grade		
			15. Well grouted? <b>yes</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.		
			16. Nearest source of possible contamination: <b>N/A</b> ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Goulds-US Pump</b> Model number <b>14JHC</b> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <b>280</b> ft. capacity <b>1200</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
18. Elevation:	19. Remarks: <b>We didn't install a gearhead or driveshaft.</b>		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter-Wilson Drilg. Co. 208</b> Business name License No. Address <b>Box A Garden City, Ks.</b> <i>[Signature]</i> Date <b>5-20-77</b> Authorized representative		

30306  
 Sec 16  
 NW SE NW  
 1/4 1/4 1/4  
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Professionals

**MINTER-WILSON DRILLING CO.**  
INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

BUD KOHART  
NEADE COUNTY  
11-23-76

Location: NW 16-30-30 7 miles south of Copelan, 1 east  $\frac{1}{2}$   
south

Static Water Level- 170'

Test #1

0	3	Top soil
3	8	Brown clay
8	33	Fine sand
33	61	Brown sandy clay
61	97	Fine to med. sand and gravel
97	111	Brown and gray clay
111	256	Fine to med. sand and gravel
256	288	Brown sandy clay
288	404	Fine to med. sand and gravel
404	410	Brown sandy clay
410	446	Fine to med. sand and gravel
446	470	Brown clay

T.D. 446