USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County	Township name	Fraction	Section number	Town number	Range number
	Meade	Mertlla	NE. NE. SE¼	30	T 30 S	R 30 W

Distance and direction from nearest town or city: 9 mi. S. of Copeland

Street address of well location if in city:

3 Owner of well: Lawrence Koehn

Address: Copeland, Kansas

Locate with "X" in section below:

Sketch map:



4 Well depth: 315 ft. Date of completion 2/27/75
Well diameter 5 in.

5 ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug
☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary

6 Use: ☒ Domestic ☐ Public supply ☐ Industry
☐ Irrigation ☐ Air conditioning ☐ Commercial
☐ Test well ☐

7 Casing: Material RMP Height: above/below
Threaded ☐ Welded ☐ Surface 24 in.
Diam. Weight ___ lbs./ft.
5 in. to 315 ft. depth Drive shoe? ☐ Yes ☒ No
___ in. to ___ ft. depth

2

Type and color of material	From	To
Overburden	0	183
Sand and gravel	183	285
Sand, gravel and clay stks.	285	300
Coarse sand	300	315
(use a second sheet if needed)		

8 Screen:
Manufacturer Sunflower
Type R.M.P. Dia. 5"
Slot/gauze Slot Length 40'
Set between 275 ft. and 315 ft.
Fittings:
Gravel pack ☒ Yes ☐ No Size range of material 1/8

9 Static water level:
188 ft. below land surface Date 2/27/75

10 Pumping level below land surfaces:
___ ft. after ___ hrs. pumping ___ g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield 80 g.p.m.

11 Water sample submitted:
☐ Yes ☒ No Date ___

12 Well head completion:
☐ Pitless adapter 24 Inches above grade

13 Well grouted? ☒ Yes ☐ No
☒ Neat cement ☐ Bentonite ☐
Depth: From 3 ft. to 13 ft.

14 Nearest source of possible contamination: None
ft. ___ Direction ___ Type ___
Well disinfected upon completion? ☒ Yes ☐ No

15 Pump: ☒ Not installed
Manufacturer's name
Model number ___ HP ___ Volts ___
Length of drop pipe ___ ft. capacity ___ g.m.p.
Type:
☐ Submersible ☐ Turbine
☐ Jet ☐ Reciprocating
☐ Certrifugal ☐ Other

16 Remarks: elevation New building site, no contamination at present

Topography:
☐ Hill
☐ Slope
☒ Upland
☐ Valley

17 Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
T & W Water Well Serv. 142
Business name License No.
Address Box 816 Liberal
Signed [signature] Date 2/28/75
Authorized representative

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

677-H