

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Meade Co.	Fraction 1/4 1/4 SE 1/4	Section number 33	Township number T 30 S R	Range number 30 E/W
2. Distance and direction from nearest town or city: 3 East of Haskell Co. Line on Gray Co. Road 5 3/4 South Street address of well location if in city: _____			3. Owner of well: Darrell Winfrey R.R. or street: Plains, KS 67869 City, state, zip code: _____			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>26</u> in. Completion date <u>11-18-77</u> Well depth <u>440</u> ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material <u>Steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>1 ft.</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>440</u> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <u>.219</u>		
				10. Screen: Manufacturer's name <u>Johnson</u> Type <u>Johnson Galv. Di 100-16"</u> Slot/gauze <u>0-220 Plain</u> and <u>220-320 Perf.</u> Set between <u>320-350 Screen</u> and <u>350-425 ft. Perf.</u> <u>425-435 Screen</u> and <u>435-440 Perf.</u> ft. Gravel pack? <u>Yes</u> Size range of material <u>1/2 to 5/8</u>		
				11. Static water level: _____ mo./day/yr. <u>180</u> ft. below land surface Date <u>10-22-77</u>		
				12. Pumping level below land surfaces: <u>206</u> ft. after <u>2</u> hrs. pumping <u>1075</u> g.p.m. <u>220</u> ft. after <u>4</u> hrs. pumping <u>1650</u> g.p.m. Estimated maximum yield <u>1650</u> g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <u>1 ft.</u> inches above grade		
				15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
				16. Nearest source of possible contamination: ft. _____ Direction <u>N/A</u> Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: _____ Not installed Manufacturer's name <u>Gould 4 stg. 14" Bowl</u> Model number _____ HP <u>200</u> Volts _____ Length of drop pipe <u>300</u> ft. capacity <u>1200</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling 208 Business name License No. _____ Address <u>Box A, Garden City, KS 67846</u> Signed <u>[Signature]</u> Date <u>5-30-79</u> Authorized representative			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

30 300 33 1/4 5
 Sec
 1/4 5

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67840
Darrell Winfrey
6-29-77

Location: SE 33-30-30 from second curve south of
Copeland $6\frac{1}{2}$ mile south & $\frac{1}{2}$ mile west

Static Water Level- 170'

Test #1

0	1	Top soil
1	14	Brown clay
14	992	Brown clay and white rock (Tight)
92	238	Fine to med. sand and gravel (Loose)
238	253	Brown clay
253	359	Fine to med. sand and gravel (Loose)
359	365	Brown clay
365	380	Brown sandy clay 35% gravel (Loose)
380	399	Fine to med. sand and gravel 20% clay (Loose)
399	410	Brown and gray clay small streaks of white rock (Tight)
410	425	Brown sandy clay 30% gravel (Fairly Loose)
425	438	Fine to med. sand and gravel (Loose)
438	458	Brown and gray (Tight) (with white rock)
458	470	Brown gray and yellow clay (Hard)