

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County MEADE	Fraction SW 1/4 NE 1/4 SW 1/4	Section number 35	Township number T 30 S R 30	Range number 30
2. Distance and direction from nearest town or city: south of Copeland to 2ND curve 5 south 1 east 1/2 south 3/8 east				3. Owner of well: W.E. Winfrey R.R. or street: Plains, Ks67869 City, state, zip code:		
4. Locate with "X" in section below: Sketch map:				6. Bore hole dia. <u>26</u> in. Completion date <u>5-13-76</u> Well depth <u>386</u> ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material				From	To	9. Casing: Material <u>Steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>387</u> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. _____
						10. Screen: Manufacturer's name <u>Johnson Division</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauze <u>100</u> Length <u>20'</u> Set between <u>345</u> ft. and <u>365</u> ft. Perf. <u>180-240</u> and <u>270-315, 365-386</u> Gravel pack? <u>yes</u> Size range of material <u>1/4" Down</u>
						11. Static water level: _____ mo./day/yr. <u>130</u> ft. below land surface Date <u>3-16-76</u>
						12. Pumping level below land surfaces: <u>154</u> ft. after <u>3</u> hrs. pumping <u>1140</u> p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>1140</u> g.p.m.
						13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____
						14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade
						15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
						16. Nearest source of possible contamination: <u>N/A</u> ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
						17. Pump: _____ Not installed Manufacturer's name <u>Goulds US Pumps</u> Model number <u>114HC</u> HP <u>200</u> Volts _____ Length of drop pipe <u>280</u> ft. capacity <u>1100</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Winter Wilson Drilling</u> <u>208</u> Business name License No. _____ Address <u>P.O. Box A Garden City, Ks</u> Signed <u>[Signature]</u> Date <u>7-16-76</u> Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

30
T
30
R
35
S
1/4
1/4
1/4
S
W
E
S
U

Free
Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

W. E. WINFREY
Meade County
2-6-76

Location SW 35-30-30
100 Yards West Of Test #1

Static Water Level 160?

Test #

0	2	Top Soil
2	4	Brown Clay
4	28	Brown Sandy Clay
28	50	Fine Sand
50	80	Brown Clay
80	154	Fine To Med. Sand & Gravel (Loose)
154	183	Fine To Med. Sand & Gravel, Streaks Of Clay (10%)
183	230	Fine To Med. Sand & Gravel (Loose)
230	243	Fine To Med. Sand & Gravel, Streaks Of Clay (10%)
243	268	Blue Clay
268	298	Fine To Med. Sand & Gravel (Loose)
298	305	Fine To Med. Sand & Gravel, Small Streaks Of Gray Clay
305	372	Fine To Med. Sand & Gravel (Loose)
372	395	Brown & Gray Clay, Streaks Of White Rock(10%)

TD 386

20' Depth