

*The
Professionals*

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 620-276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

NAME DAVE BRYANT
COUNTY MEADE
DATE 8-5-13

LOCATION: NW 1/4 6-30-30 - FROM COPELAND - SOUTH TO FIRST CURVE,
 1 MILE WEST TO 1 ROAD, 1/4 MILE SOUTH
 ON EAST SIDE
 - 290 FT. NORTH OF EXISTING WELL

STATIC WATER LEVEL - APPROX. 300 FT.

TEST # 1

0' TO 2' - TOP SOIL
2' TO 60' - BROWN CLAY
60' TO 67' - BROWN SANDY CLAY
67' TO 75' - FINE TO MEDIUM SAND & GRAVEL
75' TO 105' - BROWN CLAY
105' TO 210' - FINE TO MEDIUM SAND & GRAVEL
210' TO 223' - BROWN CLAY
223' TO 238' - BROWN & BLUE CLAY
238' TO 290' - FINE TO MEDIUM SAND
290' TO 337' - FINE TO MEDIUM SAND & GRAVEL
337' TO 354' - BROWN CLAY
354' TO 400' - FINE TO MEDIUM SAND & GRAVEL WITH CLAY STREAKS
400' TO 412' - BROWN CLAY
412' TO 430' - BROWN CLAY WITH WHITE ROCK MIXED
430' TO 445' - BROWN YELLOW CLAY
445' TO 464' - BROWN YELLOW CLAY - TRACES OF SHALE
464' TO 480' - SHALE