

1 LOCATION OF WATER WELL		Fraction	Section Number		Township Number		Range Number	
County: Haskell		SW $\frac{1}{4}$ SW $\frac{1}{4}$ NE $\frac{1}{4}$	13		T 30 S		R 31 EW	
Distance and direction from nearest town or city? Approx. 10 mi. east & 2½ south of Sublette, Kansas				Street address of well if located within city?				
2 WATER WELL OWNER: Frank Stude				Board of Agriculture, Division of Water Resources				
RR#, St. Address, Box #: 500 S. Winter				Application Number: 10,895				
City, State, ZIP Code: Sublette, Kansas 67877								
3 DEPTH OF COMPLETED WELL: 483 ft. Bore Hole Diameter: 24 in. to 483 ft. and in. to ft.								
Well Water to be used as:								
1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)								
2 Irrigation 4 Industrial 7 Lawn and garden only 10 Observation well								
Well's static water level: 207 ft. below land surface measured on JUNE month 18 day 1980 year								
Pump Test Data: Well water was 258 ft. after 4 hours pumping 1551 gpm								
Est. Yield 1550 gpm: Well water was ft. after hours pumping gpm								
4 TYPE OF BLANK CASING USED:				Casing Joints: Glued Clamped				
1 Steel 3 RMP (SR) 6 Asbestos-Cement 9 Other (specify below) Welded X								
2 PVC 4 ABS 7 Fiberglass Threaded								
Blank casing dia 16 in. to 483 ft. Dia in. to ft. Dia in. to ft.								
Casing height above land surface 12 in., weight 36.91 lbs./ft. Wall thickness or gauge No. 219								
TYPE OF SCREEN OR PERFORATION MATERIAL:				7 PVC 10 Asbestos-cement				
1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify)								
2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)								
Screen or Perforation Openings Are:				5 Gauzed wrapped 8 Saw cut 11 None (open hole)				
1 Continuous slot 3 Mill slot 6 Wire wrapped 9 Drilled holes								
2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify)								
Screen-Perforation Dia 16 in. to 480 ft. Dia in. to ft. Dia in. to ft.								
Screen-Perforated Intervals: From 250' to 280' ft. to 320' to 380' ft. From 385' to 415' ft. to 450' to 480' ft.								
Gravel Pack Intervals: From 10 ft. to 483 ft. From ft. to ft. From ft. to ft.								
5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other								
Grouted Intervals: From 0 ft. to 10 ft. From ft. to ft. From ft. to ft.								
What is the nearest source of possible contamination: None Observed				10 Fuel storage 14 Abandoned water well				
1 Septic tank 4 Cess pool 7 Sewage lagoon 11 Fertilizer storage 15 Oil well/Gas well								
2 Sewer lines 5 Seepage pit 8 Feed yard 12 Insecticide storage 16 Other (specify below)								
3 Lateral lines 6 Pit privy 9 Livestock pens 13 Watertight sewer lines								
Direction from well How many feet ? Water Well Disinfected? Yes No X								
Was a chemical/bacteriological sample submitted to Department? Yes No X If yes, date sample								
was submitted month day year: Pump Installed? Yes X No								
f Yes: Pump Manufacturer's name Layne-Bowler Model No. HP 150 Volts								
Depth of Pump Intake 360 ft. Pumps Capacity rated at gal./min.								
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other								
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was								
completed on JUNE month 13 day 1980 year								
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 145								
This Water Well Record was completed on JULY month 17 day 1980 year under the business								
name of Henkle Drilling & Supply Co. Inc. by (signature) Bruce J. Reichmuth								
LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG	
				See attached log				
ELEVATION:								
Depth(s) Groundwater Encountered 1. ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)								

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.

DRILLERS TEST LOG

CUSTOMERS NAME Frank Stude DATE 3-18-80
STREET ADDRESS TEST # 1
CITY & STATE Sublette, KS. DRILLER Rector
COUNTY Haskell QUARTER NE SECTION 13 TOWNSHIP 30 RANGE 31

LOCATION 300' N. of current well

WELL LOCATION

[illegible]

HENKLE DRILLING & SUPPLY CO., INC.

GARDEN CITY, KANSAS

SURLETTE, KANSAS

Phone 276-3278

Phone 675-4311

TEST HOLES

DOMESTIC WELLS

STOCK VALUES

IRRIGATION & INDUSTRIAL WELLS