


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Haskell	Township name	Fraction NW NW NE	Section number 20	Town number 30S	Range number 31W	
Distance and direction from nearest town or city: Approx. 7 mi. E & 3 mi. S of Sublette Street address of well location if in city:				3 Owner of well: Robert Hammer R.R. Sublette, Kansas Address:			
Locate with "X" in section below: <div style="text-align: center;">N  S 1 Mile</div>				Sketch map:			
2 Type and color of material				From	To		
				Well drilled near TH 2-75 (see attached)			
				which is located near the NW corner of the			
				NE 1/4, Sec. 20, T30S, R31W, Haskell County, Ks.			
				4 Well depth: 418 ft. Date of completion 4/9/75 Well diameter 28 in.			
				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well			
				7 Casing: Material Stl Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. to 418 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth			
				8 Screen: Manufacturer Brown & Foster Type Louver & Mill slot Dia. 16" Slot/gauze 1/8" Length 194' Set between 224 ft. and 418 ft. Fittings: 1, 2 - 9 mm Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material _____			
				9 Static water level: 176 ft. below land surface Date 3/11/75			
				10 Pumping level below land surfaces: 239 ft. after 1 1/2 hrs. pumping 1791 g.p.m. 246 ft. after 1 hrs. pumping 2144 g.p.m. Estimated maximum yield 2200 g.p.m.			
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____			
				12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> _____ inches above grade			
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 10 ft.			
				14 Nearest source of possible contamination: unk ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Layne Model number 14 TL HP 175 Volts _____ Length of drop pipe 300 ft. capacity 2000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne-Western Company 150 Business name License No. _____ Address Garden City, Ks Signed [Signature] Date 5/19/75 Authorized representative			

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

Layne-Western Company, Inc.



- WATER SUPPLY SERVICES SINCE 1924

TEST DRILLING • WATER WELLS • PUMPS
P.O. Box 686 - P. Hwy. 50
Garden City, Kansas 67346

TEST HOLE

No. 2-75

Driller Gill

Elevation of Test Hole

Static Water Level 200

Measured _____ Hours After Completion

_____ 1/4 NW 1/4 Sec. 20 of T 30 _____,
R 31 _____, Haskell Co., Kansas.

[illegible]

Remarks: