


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County HASKELL	Fraction NE 1/4 SW 1/4 NW 1/4	Section number 29	Township number T 30 S R 31	Range number 4/W
2. Distance and direction from nearest town or city: From the fairgrounds at Sublette 1/4 south 5/8 east 3/10 south				Owner of well: Clarence Schmidt R.R. or street: Cimarron, Ks. 67835 City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. Steel Completion date 5-19-76 Well depth 450 ft.		
		7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary				
		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				
5. Type and color of material		From		To		9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 451 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219
						10. Screen: Manufacturer's name Johnson Division Type Galv Dia. 16 in. Slot/gauze 100 Length 20 ft. Set between 420 ft. and 440 ft. Pack 240-290 ft. and 360-420 ft. 450 Gravel pack? Yes Size range of material 1/2" Down
						11. Static water level: <input type="checkbox"/> mo./day/yr. 200 ft. below land surface Date 7-2-76
						12. Pumping level below land surfaces: 229 ft. after 2 hrs. pumping 919 g.p.m. 240 ft. after 4 hrs. pumping 1245 g.p.m. Estimated maximum yield 1245 g.p.m.
						13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date
						14. Well head completion: <input type="checkbox"/> Pitless adapter 70 inches above grade
						15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 70 ft.
						16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
						17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds US pump Model number 14JHC HP 200 Volts Length of drop pipe 360 ft. capacity 1245 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						(Use a second sheet if needed)
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name P.O. Box A Garden City, Ks License No. Address 7-16-76 Date Signed M. Wilson Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Industrial
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269

P.O. Box 493

GARDEN CITY, KANSAS 67846

Clarence Schmidt

Haskell County

9-5-75

Location: NW 29-30-31

From Fair Grounds at Sublette, 4 miles South, 5 1/2
miles East, 3/10 mile South

Test # 3

0	2	Top Soil
2	93	Brown Sandy Clay
93	277	Fine to Med. Sand & Gravel (Loose)
277	293	Fine to Med. Sand & Gravel, Streaks of Clay (25%)
293	307	Brown Sandy Clay
307	323	Brown Sandy Clay mixed with Gray Clay
323	362	Blue Clay (Tight)
362	442	Fine to Med. Sand & Gravel (Loose)
442	450	Fine to Med. Sand, Streaks of Clay (20%)
450	487	Fine Sand mixed with Gray & Brown Clay (Tight)
487	500	Gray & Yellow Clay (Tight)

TD 450'