


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County HASKELL	Fraction NE 1/4 SW 1/4 NE 1/4	Section number 34	Township number T 30 S	Range number R 31 W
X Distance and direction from nearest town or city: from SE corner of Sublette, 8 1/2 east 1 1/4 south 100 Yds. east.			3. Owner of well: Clarence Schmidt			
Street address of well location if in city: SEWARD Co. line 10E 3/4 N.C.			R.R. or street: Copeland, Ks. 67836			
City, state, zip code:						
4. Locate with "X" in section below:			Sketch map:			
						
5. Type and color of material			From	To	6. Bore hole dia. 26 in. Completion date 6-21-76 Well depth 470 ft.	
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material Steel Height: Above or Below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 26.87 lbs./ft. Dia. 16 in. to 477 ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. 250 m/c	
					10. Screen: Manufacturer's name Johnson Division Type Galv. Dia. 16" Slot/gauze 100 Length 201 30' m/c Set between 430 ft. and 460 ft. Perf. 220-350 ft. and 410-430, 460-470 ft. Gravel pack? yes Size range of material 1/8" Down	
					11. Static water level: <input type="checkbox"/> mo./day/yr. 202 ft. below land surface Date 6-11-76	
					12. Pumping level below land surfaces: 226 ft. after 3 hrs. pumping 1575 g.p.m. 226 ft. after 3 hrs. pumping 1575 g.p.m. Estimated maximum yield 1575 g.p.m.	
					13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date 6-11-76	
					14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
					15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
					16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds US Pumps Model number 11-JHC HP 150 Volts 208 Length of drop pipe 360 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
			(Use a second sheet if needed)			
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Winter Wilson Drilling 208 Business name P.O. Box A Garden City, KS Address 1000 S. 1st St. Topeka, KS 66608 Signed Winter Wilson Date 6-21-76 Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269

P.O. Box 493

GARDEN CITY, KANSAS 67846

CLARENCE SCHMIDT
HASKELL COUNTY
2-23-76

Location: NE 34-30-31
100 yards east, 100 ft. south of Test # 1

Static Water Level: 180'

Test # 6

0	1	Top Soil
1	4	Brown Clay
4	95	Brown Sandy Clay
95	170	Fine to Med. Sand & Gravel (Loose)
170	201	Fine to Med. Sand & Gravel, Streaks of Clay (10%)
201	217	Fine to Med. Sand, Streaks of Clay (10%)
217	290	Fine to Med. Sand & Gravel (Loose)
290	303	Brown Clay, Streaks of Fine to Med. Sand & Gravel (30%)
303	340	Fine to Med. Sand & Gravel (Loose)
340	350	Fine to Med. Sand & Gravel, Streaks of Clay (10%)
350	380	Brown Sandy Clay & Blue Clay mixture
380	408	Blue Clay
408	418	Fine to Med. Sand & Gravel, Streaks of Clay (10%) (Loose)
418	460	Fine to Med. Sand & Gravel (Loose)
460	470	Fine to Med. Sand & Gravel, Streaks of Clay (10%) (Loose)
470	480	Gray, Brown & White Clay (Hard)

T.O. 470'