

[illegible]

*The
Professionals*

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269

• P.O. Box A

• GARDEN CITY, KANSAS 67846

Dave Bryant
Haskell County
4/1/05

Location: NW $\frac{1}{4}$ 15-30-31 - From SE corner of Sublette - 7 miles east to
Road VV, 2 $\frac{1}{2}$ miles south, $\frac{1}{2}$ mile east & 40 ft.
north - 2,140 ft. south & 405 ft. west of
existing well

Static Water Level 300 ft.

Test #5

0' to 1' - Top soil
1' to 10' - Brown clay
10' to 77' - Brown sandy clay
77' to 88' - Fine to medium sand & gravel
88' to 97' - Brown clay
97' to 118' - Fine to medium sand & gravel
118' to 129' - Brown clay
129' to 153' - Fine to medium sand & gravel
153' to 189' - Brown clay
189' to 194' - Fine to medium sand & gravel
194' to 203' - Brown clay
203' to 289' - Fine to medium sand & gravel
289' to 302' - Brown blue clay
302' to 339' - Fine to medium sand & gravel - 10% clay
339' to 369' - Brown blue clay
369' to 400' - Fine to medium sand & gravel - 10% clay
400' to 430' - Fine to medium sand & gravel
430' to 475' - Fine to medium sand & gravel - small clay strips
475' to 482' - Brown clay
482' to 488' - Brown clay brown rock 40%
488' to 504' - Brown yellow clay
504' to 515' - Shale