


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Haskell</b>	Fraction <b>NW 1/4 NW 1/4 NE 1/4</b>	Section number <b>10</b>	Township number <b>T 30 S</b>	Range number <b>R 32 E</b>
2. Distance and direction from nearest town or city: <b>2 E. &amp; 1 1/4 S. of Sublette</b> Street address of well location if in city:			3. Owner of well: <b>Eldon Weeks</b> R.R. or street: <b>Sublette, KS 67877</b> City, state, zip code:			
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile			Sketch map: 		6. Bore hole dia. <b>26</b> in. Completion date <b>11-22-76</b> Well depth <b>463</b> ft.	
5. Type and color of material <b>See attachment</b>			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material <b>Steel</b> Height <b>Above</b> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36</b> lbs./ft. Dia. <b>16</b> in. to <b>463</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>219</b>			
			10. Screen: Manufacturer's name <b>Brown</b> Type <b>Louvered</b> Dia. <b>16"</b> Slot/gauze <b>125</b> Length <b>100'</b> Set between <b>400</b> ft. and <b>350</b> ft. <b>325</b> ft. and <b>275</b> ft. Gravel pack? <b>Yes</b> Size range of material <b>1/4 x 1/8</b>			
			<input checked="" type="checkbox"/> Static water level: <b>283</b> ft. below land surface Date <b>11-24-76</b> mo./day/yr.			
			12. Pumping level below land surfaces: <b>261</b> ft. after <input type="checkbox"/> hrs. pumping <b>1451</b> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.			
			13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.			
			14. Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> inches above grade			
			15. Well grouted? <b>Yes</b> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.			
			16. Nearest source of possible contamination: <b>None Observed</b> ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other						
(Use a second sheet if needed)						
18. Elevation: <b>Flat</b> Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Henkle Drlg. &amp; Supply 145</b> Business name License No. Address <b>Box 639 Garden City, KS</b> Signed <b>E. L. Bethune</b> Date <b>12-7-76</b> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

## DRILLERS TEST LOG

CUSTOMERS NAME Eldon Weeks DATE 11-15-76  
STREET ADDRESS \_\_\_\_\_ TEST # 1 E. Loq  
CITY & STATE Sublette, KS DRILLER Rector  
COUNTY Haskell QUARTER NE SECTION 10 TOWNSHIP 30 RANGE 32

LOCATION 250' E. of N.W. corner of 1/4

%	DRILLED FOOTAGE			WELL LOCATION	
	From	Pay	To	Description of Strata	Static Water Level Proposed Well Depth
	0		2	Top soil	
	2		67	Brown clay and fine sand	
	67		95	Sand fine med. coarse and small gravel	
	95		100	Brown clay	
	100		115	Brown sandy clay and sand	
	115		140	Sand fine med. coarse, med. small and sandy clay	
	140		170	Sand fine med. coarse, small gravel, some caliche clay	
70	170	14	274	Sand fine med. coarse and small gravel, loose, used lots of water	
	274		279	Brown clay and fine sand	
65	279	34	313	Sand fine med. coarse and small gravel, loose, used lots of water (very good)	
	313		320	Brown and blue clay and sand sts.	
55	320	25	345	Sand fine med. coarse, small gravel and small clay sts., loose, used water	
65	345	20	365	Sand fine med. coarse and small gravel, loose, used lots of water	
	365		380	Brown clay, caliche and sand sts.	
55	380	14	394	Sand fine med. coarse small gravel, very small clay and lime rock sts., used water	
	394		420	Brown clay and lime rock	
2	420	40	460	Brown clay, lime rock, brown sandstone sts. and sand, used water	
	460		560	Blue clay and few rock ledges	
		147			
				TOTAL DEPTH OF WELL 463 FT.	
				Set up West	
				Dig pit on the North	

GARDEN CITY, KANSAS  
PHONE 276-3278

HENKLE DRILLING & SUPPLY CO., INC.  
IRRIGATION HEADQUARTERS

SUBLETTE, KANSAS  
PHONE 675-4311

TEST HOLES\*\*\*\*\*STOCK WELLS\*\*\*\*\*IRRIGATION AND INDUSTRIAL WELLS\*\*\*\*\*