


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82g-1201-1215

T		R		EW		sec	1/4	1/4	1/4	No	

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Haskell	Township name	Fraction NW, NW, NW³/₄	Section number 10	Town number T 30 S	Range number R 32 W																														
Distance and direction from nearest town or city: 1 mile east & 1 South of Sublette Street address of well location if in city:				3 Owner of well: Eldon Weeks Address: Sublette, KS																																
Locate with "X" in section below: <div style="text-align: center;">N  W E <div style="text-align: center;">S 1 Mile</div></div>		Sketch map:		4 Well depth: <u>397'</u> ft. Date of completion <u>8-28</u> Well diameter <u>12 1/4</u> in.																																
2 <table border="1" style="width:100%; border-collapse: collapse;"><thead><tr><th style="width:60%;">Type and color of material</th><th style="width:10%;">From</th><th style="width:10%;">To</th></tr></thead><tbody><tr><td>See Attachment</td><td></td><td></td></tr><tr><td> </td><td></td><td></td></tr><tr><td> </td><td></td><td></td></tr><tr><td> </td><td></td><td></td></tr><tr><td> </td><td></td><td></td></tr><tr><td> </td><td></td><td></td></tr><tr><td> </td><td></td><td></td></tr><tr><td> </td><td></td><td></td></tr><tr><td> </td><td></td><td></td></tr></tbody></table>				Type and color of material	From	To	See Attachment																											5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				Type and color of material	From	To																														
				See Attachment																																
6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/> _____																																				
7 Casing: Material <u>Plastic</u> Height: <u>above</u> below <u>Glued</u> threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. Diam. _____ Weight _____ lbs./ft. _____ <u>6-5/8</u> in. to <u>397</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth																																				
8 Screen: Manufacturer <u>Jet Stream</u> Type <u>Slotted</u> Dia. <u>6-5/8"</u> Slot/gauze <u>.040</u> Length <u>40'</u> Set between <u>397</u> ft. and <u>377</u> ft. _____ Fittings: <u>357'</u> & <u>337'</u> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>1/2</u>																																				
9 Static water level: <u>Not Pumped</u> _____ ft. below land surface Date _____																																				
10 Pumping level below land surfaces: <u>Not Test P</u> _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.																																				
11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____																																				
12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade																																				
13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> <u>Concrete</u> Depth: From <u>0</u> ft. to <u>10</u> ft.																																				
14 Nearest source of possible contamination: <u>Septic Tank</u> ft. <u>150'</u> Direction <u>South</u> Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																																				
15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																																				
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley <div style="text-align: center;">Flat</div>				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & Supply 145 Business name _____ License No. _____ Address <u>639 Garden City, KS</u> Signed <u>Richard Henkle</u> Authorized representative																																

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Eldon Weeks

DATE 8-26-75

STREET ADDRESS

TEST # Housewell

CITY & STATE Sublette, KSDRILLER Livingston

COUNTY Haskell QUARTER NW SECTION 10 TOWNSHIP 30 RANGE 32

LOCATION 50' NW of old well.

%	DRILLED FOOTAGE		Description of Strata	Static Water Level
	From	Pay To		Proposed Well Depth
	0	2	Top soil	
	2	70	Brown clay, caliche & few sand st.	
	70	92	Sand fine to med, small to med gravel & few clay st.	
	92	100	Brown sandy clay & few sand st.	
	100	120	Sand fine to med, small to large gravel	
	120	140	Brown clay	
	140	200	Sand fine to med, small to med gravel, few cemented ledges & clay st.	
	200	210	Brown sandy clay	
	210	256	Sand fine to med coarse, small to med gravel & few clay st.	
	256	280	Brown & yellow clay & few sand st.	
	280	300	Sand fine to med coarse, small gravel	
	300	340	Brown & gray clay & fine sand st & rock ledges	
60	340	26 366	Sand fine to med coarse, small gravel	
	366	380	Brown sandy clay	
65	380	16 396	Sand fine to med coarse, small gravel	
	396	430	Brown sandy clay & limerock	
	430	450	Yellow soapstone & limestone	
	450	460	Weathered shale	
			6 5/8" Plastic Casing	
			397 - 377 Perf.	
			377 - 357 Plain	
			357 - 337 Perf.	
			337 - 0 Plain	
			Henkle A Gravel Pack	
			7 sacks of Revert	
			1 gallon of chlorine	

ARDEN CITY, KANSAS

HONE 276-3278

HENKLE DRILLING & SUPPLY CO., INC.

IRRIGATION HEADQUARTERS

SUBLETTE, KANSAS

PHONE 675-4311

EST HOLES*****STOCK WELLS*****IRRIGATION AND INDUSTRIAL WELLS*****