


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Haskell</b>	Township name	Fraction <b>NE SW NW</b>	Section number <b>12</b>	Town number <b>30S</b>	Range number <b>32W</b>
Distance and direction from nearest town or city: <b>5 miles E, 1 1/2 So. and 1/4 East of Sublette. Approx.</b> Street address of well location if in city:				3 Owner of well: <b>Viola Baker</b> Address: <b>516 1/2 North Street Garden City, Kansas</b>		
Locate with "X" in section below: N  W E S 1 Mile				Sketch map:		
2 Type and color of material				From	To	4 Well depth: <b>425</b> ft. Date of completion <b>3/27/75</b> Well diameter <b>28</b> in.
Well drilled near TH -174 (see attached),						5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
which is located at the center of the SW 1/4,						6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>
Sec. 12, T30S, R32W, Haskell County, Ks.						7 Casing: Material <b>Stl</b> Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. Diam. <b>16</b> in. to <b>425</b> ft. depth Weight <b>37</b> lbs./ft. Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to ft. depth
						8 Screen: Manufacturer <b>Brown &amp; Foster</b> Type <b>Louver &amp; Millslot</b> Dia. <b>16</b> Slot/gauze <b>1/8"</b> Length <b>223'</b> Set between <b>2 02</b> ft. and <b>425</b> ft. Fittings: <b>1-9MM</b> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material
						9 Static water level: <b>205</b> ft. below land surface Date <b>3-1-75</b>
						10 Pumping level below land surfaces: <b>215</b> ft. after <b>5</b> hrs. pumping <b>1016</b> g.p.m. <b>231</b> ft. after <b>1</b> hrs. pumping <b>2276</b> g.p.m. Estimated maximum yield <b>2500</b> g.p.m.
						11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
						12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <b>0</b> ft. to <b>10</b> ft.
						14 Nearest source of possible contamination: <b>Unk</b> ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Layne</b> Model number <b>12R</b> HP <b>108</b> Volts Length of drop pipe <b>280</b> ft. capacity g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
16 Remarks: elevation				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Layne-Western Co</b> <b>150</b> Business name License No. Address <b>Garden City, Ks.</b> Signed <b>A. L. Minter</b> Date <b>5-19-75</b> Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

***Layne-Western Company, Inc.***



## WATER SUPPLY SERVICES SINCE 1924

TEST DRILLING • WATER WELLS • PUMPS

R 32, Haskell Co.,           .

[illegible]**Remarks:**