


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Haskell	Fraction NE 1/4 SW 1/4 NE 1/4	Section number 22	Township number T 30 S R 32	Range number 32 (E/W)
2. Distance and direction from nearest town or city: 2 east, 3 south, Street address of well location if in city: 1/4 west of Sublette				3. Owner of well: Floyd Leonard, Jr. R.R. or street: City, state, zip code: Sublette, Ks. 67877		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile				Sketch map: 		
5. Type and color of material				From	To	6. Bore hole dia. 26 in. Completion date 8-31-77 Well depth 425 ft.
						7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
						8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
						9. Casing: Material steel Height: Above ground 12 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 426 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250
						10. Screen: Manufacturer's name Johnson Type galv. Dia. 16" Slot 3/16" Length 40 ft. Set between 360 ft. and 400 ft. Perf: 250-360 ft. and 400-425 ft. Gravel pack? yes Size range of material 1/2" down
						11. Static water level: 204 ft. below land surface Date 7-9-77
						12. Pumping level below land surfaces: 251 ft. after 2 hrs. pumping 900 g.p.m. 264 ft. after 4 hrs. pumping 1200 g.p.m. Estimated maximum yield 1200 g.p.m.
						13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date
						14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
						15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
						16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
						17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds - US Pump Model number 12JHC HP 200 Volts <input type="checkbox"/> Length of drop pipe 340 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name Box A Garden City, Ks. License No. 11-29-77 Signed [Signature] Date 11-29-77 Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Professional

MINTER-WILSON DRILLING CO.
INCORPORATED

Installation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67840

FLOYD LEOANRD JR.
HASKELL COUNTY
6-28-77

Location: NE 22-30-32 approx. 1094 ft. east of existing w
well

Static Water Level - 210'

Test #3

0	1	Top soil
1	53	Brown clay
53	62	Fine to med. sand and gravel 30% clay
62	113	Brown clay
113	179	Fine to med. sand and gravel (Loose)
179	185	Brown clay
185	199	Fine to med. sand and gravel (Loose)
199	210	Brown clay
210	230	Fine to med. sand and gravel (Loose)
230	233	Brown clay
233	263	Fine to med. sand and gravel (Loose)
263	282	Brown clay
282	290	Fine to med. sand and gravel 10% clay (Loose)
290	425	Fine to med. sand and gravel (Loose)
425	448	Brown gray and yellow clay (Tight)
448	455	Shale (Hard)

250 Plain
110 Peff
40 Screen
25 Perf