


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Haskell	Fraction NW 1/4 SW 1/4 NW 1/4	Section number 24	Township number T 30 S R 32 E/W	Range number
2. Distance and direction from nearest town or city: Sublette, Kansas Street address of well location if in city:	SE 3 1/4 S of		3. Owner of well: Ron Winter R.R. or street: R.R. City, state, zip code: Sublette, Kansas		
4. Locate with "X" in section below: 	Sketch map: 1313' N and 660' E of the SW corner of the NW 1/4, Sec. 24, T30S, R32W, Haskell County, Kansas.			6. Bore hole dia. 28 in. Completion date 3-31-77 Well depth 401 ft.	
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Top soil			0	5	9. Casing: Material Stl Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 37 lbs./ft. Dia. 16 in. to 201 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219
Tan sandy clay			5	58	10. Screen: Manufacturer's name Foster, Doerr Type Louvered, Millslot 16" Slot/gauze 1/8" Length 200 Set between 201 ft. and 401 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3.8mm
Tan clay			58	94	11. Static water level: <input type="checkbox"/> mo./day/yr. 178 ft. below land surface Date 2-14-77
Fine to coarse sand			94	230	12. Pumping level below land surfaces: 208 ft. after 1 hrs. pumping 2015 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 2500 g.p.m.
Tan clay			230	240	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.
Fine to coarse sand, fine gravel			240	296	14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> <input type="checkbox"/> Inches above grade
Blue clay			296	334	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
Fine to coarse blue sand			334	400	16. Nearest source of possible contamination: unk ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Hard tan clay			400	416	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Layne & Bowler Model number 12TL HP 12.5 Volts 1400 Length of drop pipe 280 ft. capacity 1400 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Hard sandy tan clay			416	448	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne-Western Co., Inc. 102 Business name License No. Address Garden City, Kansas Signed [Signature] Date 12 Jan 77 Authorized Representative
Very fine sand			448	454	
Bed rock hard			454	500	
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:				

Forward the white, blue and pink copies to the Department of Health and Environment