


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Haskell	Fraction NE 1/4 SW 1/4 SW 1/4	Section number 25	Township number T 30 S	Range number R 32 E/W
2. Distance and direction from nearest town or city: 4 1/2 miles S of Sublette		3. Owner of well: Don & Mildred Bird		City, state, zip code: Sublette, Kan 67877		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date Well depth 538 ft. 3/23/78		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Overburden		0	2	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 42.5 lbs./ft. Dia 14 in. to 538 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gauge No. 250		
Top Soil		2	200	10. Screen: Manufacturer's name Lakewood Pipe Type Steel Dia. 16 Slot/gauze 1/8 Length 3 Set between 328 ft. and 360 ft. 380 ft. and 538 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8-1/4		
Sd. & Gravel		200	220	11. Static water level: <input type="checkbox"/> mo./day/yr. 244 ft. below land surface Date 3/23/78		
Sd. & Gravel		220	240	12. Pumping level below land surfaces: NA ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
Med. & Coarse Sd. w/Clay		240	260	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____		
Coarse Sd. & Gravel		260	300	14. Well head completion: ____ Pitless adapter NA ____ Inches above grade		
Sd. & Gravel		300	340	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Sd. & Gravel w/Rock Strks.		340	420	16. Nearest source of possible contamination: ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Med. Sd. & Clay		420	460	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Fine Sd. & Sd. stone		460	560	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. KTM DRILLING, INC. 225 Business name License No. Address Box 1385, Guymon, Okla. Signed [Signature] Date 4/4/78 Authorized representative		
Red Bed		560	600			
(Use a second sheet if needed)						
18. Elevation:		19. Remarks: 10A Johnson Screen 16" Steel 1100 Slot 360-380 16A Cropland				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5