USE TYPEWRITER OR BALL A POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

## WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

127										
County	Fraction	Section	number	Township number	Range number					
Location of well:   Haskell   Sid 1/4   Sid 1/4   SE 1/4		/4 28	3	1 30 s	R 32	E 🕖				
2. Distance and direction from nearest town or city: 5 5 & 2 1/2E 3. Owner of well:			II: No	Vorman Sherman						
Street address of well location if in city: Of Sublette, Ks. R.R. or street: 600 W:				ichita						
				6. Bore hole dia. 6. Bore hole dia.						
4. Locate with "X" in section below:  N				Well depth 260 ft. 6-18-76						
ī [				7 Cable tool 🗶 Rotary Driven Dug						
NW NE				Hollow rod Jetted Bored Reverse rotary						
W SW SE -				8. Use: Domestic Public supply Industry Irrigation Air conditioning Stock Lawn Oil field water Other						
							9. Casing: Material			
				1 Mile						
				5. Type and color of material			То	Diain. toft. depth gage No		
			<u> </u>	10. Screen: Manufacturer's n	damePOSTE	<b>e</b> _				
Top soil and clay			90	Type MILLS Lot		000				
Coarse sand, gravel, and clay streaks			150	Slot/ama 100 Length — 2433 Set between 177 ft. and 460 ft.						
				ft. o	ind	<u></u> #.],				
Coarse sand and fine gravel			180	Gravel pack?						
11			210	<ol> <li>Static water level:</li> <li>ft. below land sur</li> </ol>		day/yr.				
Coarse sand, large gravel (७") and clay				12. Pumping level below land	surfaces:					
				262 ft. after hrs. pumping /4						
streaks			2 <b>4</b> 0	Estimated maximum yield —		g.p.m.				
Coarse sand		240	270	13. Water sample submitted:		day/yr.				
				Yes No	Date	<b></b> ∤				
Coarse sand, gravel, and brown and blue				14. Well head completion: Pitless adapter	/ 2 Inches above gr	ade				
clay streaks			300							
Coarse sand and gravel			330	15. Well grouted? <u>UES</u> With: Neat cement						
			7.00	Depth: From ft. to ft. to						
11 11			360	ft	Type					
Coarse sand and gravel 390–410 Sand stone			420	Well disinfected upon comple	tion? Yes 🗶	No				
Clay and med. sand streaks			450	17. Pump: Manufacturer's name	Not installed Ci	este me				
			,	Model number 15/10/54	HP 160 Volts					
Fine sand and clay		450	480	Length of drop pipe <u>380</u> Type:	L. ft. capacity <b>2000</b>	j.p.m.				
				Submersible	Turbine					
(Use a second sheet if needed)				Jet Centrifugal	Reciproce	ating S				
18. Elevation: 19. Remarks:			·	20. Water well contractor's of		—— "				
				This well was drilled under m	y jurisdiction and this re	eport				
Topography:				is true to the best of my knowledge and belief.						
— Hill			Clemen'S IRR. DRh. 330 License No.							
Slope V Unland			Address Por Box 499 Libi Ral 10							
Upland Valley				Signed Authorized rep	resentative Date	20.10				
Forward the white, blue and pink copies to the Department	of Health and Environment				Form WWC					