


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Haskell	Township name	Fraction N $\frac{1}{2}$, NE $\frac{1}{4}$	Section number 2	Town number T 30 S	Range number R 33 W
Distance and direction from nearest town or city: 1 $\frac{1}{4}$ W. of Sublette Street address of well location if in city:				3 Owner of well: Anna Becker % Harry Garrett Address: Sublette, Kansas 67877		
Locate with "X" in section below: N  W E S 1 Mile				Sketch map:		
2				4 Well depth: 474 ft. Date of completion 4-29-75 Well diameter 26 in.		
Type and color of material				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
See Attachment				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
				7 Casing: Material Steel Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. 16 in. Weight 36 lbs./ft. 16 in. to 474 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				8 Screen: Manufacturer Brown Type Louvered Dia. 16" Slot/gauze 1/8" Length 110' Set between 434 ft. and 474 ft. Fittings: 340 & 410' 1/4 to 1/8 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material		
				9 Static water level: 274 ft. below land surface Date 4-29-75		
				10 Pumping level below land surfaces: 350 ft. after hrs. pumping 1600 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
				12 Well head completion: 12 <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.		
				14 Nearest source of possible contamination: None Observed ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(use a second sheet if needed)						
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope Flat <input type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & Supply 145 Business name License No. Address Box 639 Garden City, Ks. Signed James W. Henkle Date 5/9/75 Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Mrs. Anna Becker DATE 4-17-75
 STREET ADDRESS 70 Harry Garrett TEST # 1 L.H.
 CITY & STATE Sublette, KS DRILLER Henderhan
 COUNTY Haskell QUARTER NE SECTION 2 TOWNSHIP 30 RANGE 33

LOCATION 50 ft. south & 15 ft. east of old well.

WELL LOCATION

%	DRILLED from	FOOTAGE Pay to	Description of Strata	Static Water Level <u>257</u> Proposed Well Depth
	0	2	Top soil	
	2	70	Brown clay sandy clay caliche, limerock ledges & fine sand st.	
	70	74	Sand fine to medium loose	
	74	81	Brown clay	
	81	90	Sand fine medium coarse, small brown gravel, loose in places, used water	
	90	111	Sand fine to medium, cemented sand & sandy clay mixed.	
	111	120	Brown sandy clay	
	120	148	Sand fine medium coarse small, some medium gravel brown, gravel hard cemented ledges, drills rough, used water	
	148	156	Brown sandy clay & cemented sand ledges	
	156	167	Sand fine to medium, coarse, small some medium gravel, brown gravel, hard cemented ledges, used water.	
	167	175	Brown sandy clay & cemented sand st.	
70	175	50 300	Sand fine medium coarse, small few medium gravel brown & some tan gravel loose & some rough ledges	
75	300	60 360	Sand fine medium coarse small, medium gravel brown & some tan gravel loose, used water, few clay st. & cemented ledges.	
70	360	40 410	Sand fine medium coarse small, some medium gravel brown & tan gravel loose, used water, few clay st. & few cemented ledges more hard ledges from 380' to 410'	
60	410	6 416	Sand fine medium coarse small medium gravel, brown gravel & a lot of clay & cemented sand mixed	
40	416	2 418	Sand fine to medium & cemented sand	
	418	436	Brown sandy clay very sticky hard ledges. Fine sand st, cemented sand st.	
40	436	37 473	Sand fine to small & cemented st. some sticky clay st.	
	473	475	Hard rock ledge	
	475	480	Brown green & yellow soapstone	
			TOTAL DEPTH OF WELL 474 FT	
			Sat up east	
			Dig pit on the south	