

DRILLERS TEST LOG

CUSTOMERS NAME Harry Wright DATE 12-3-79
STREET ADDRESS _____ TEST # 1 E. Log yes
CITY & STATE Sublette, Ks. 67877 DRILLER Mai
COUNTY Haskell QUARTER NE SECTION 11 TOWNSHIP 30 RANGE 33

LOCATION 620' East & 100' North of SW corner of NE 1/4 Sec.

Gas line 120' West of test #1				WELL LOCATION	
#	DRILLED FROM	PAY	FOOTAGE TO	DESCRIPTION OF STRATA	STATIC WATER LEVEL PROPOSED WELL DEPTH 262'
	0		2	Top Soil	
	2		42	Brown clay & calichee	
	42		75	Sand fine to med. few clay sts.	
	75		103	Sand fine to med. coarse small to med. gravel few large gravel.	
	103		123	Brown sandy clay, caliche & sand sts.	
	123		250	Sand fine to med. coarse small to med. gravel, few large gravel few clay sts. loose in places water.	uses
65	250	100	375	Sand fine to med. coarse small to med. gravel, limerock ledges, loose	few
	375		386	Brown sandy clay & limerock.	
60	386	16	402	Sand fine to med. coarse small to med. gravel loose few sandy clay stringers.	
	402		411	Brown clay, limerock & sand fine to med. coarse.	
	411		426	White clay, brown sandy clay & limerock	
	426		448	Yellow soapstone, white clay, limerock & limerock ledges.	
	448		456	Blue shale	
FAIR	456	12	468	Sandstone blue shale sts.	
	468		495	Blue shale	
FAIR	495	29	524	Sandstone & blue shale sts.	
	524		546	Blue shale	
GOOD	546	34	580	Sandstone uses water added bran to keep circ. Few blue shale & weathered shale sts.	
VERY GOOD	580	45	625	White sandstone few weathered shales sts. uses water, fairly tight,	
	625		626	Hard ledge.	
				Total Depth of Well 626'	
				4 Sacks quik gel 1/2 sack bran	
				Set up WEST	
				Pits on NORTH	

HENKLE DRILLING & SUPPLY CO., INC.

GARDEN CITY, KANSAS

Phone 276-3278

SUBLETTE, KANSAS

Phone 675-4311

TEST HOLES

DOMESTIC WELLS

STOCK WELLS

IRRIGATION & INDUSTRIAL WELLS