


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Haskell	Fraction SW 1/4 SE 1/4 NE 1/4	Section number 19	Township number T 30 S R 34 E	Range number 34			
2. Distance and direction from nearest town or city: 7 S.W. of Satanta Street address of well location if in city:			3. Owner of well: Miller Feed Yard R.R. or street: Satanta, KS 67870 City, state, zip code:						
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia: 10 5/8 in. Completion date 7-7-76 Well depth: 362 ft.					
5. Type and color of material See attachment		From		To		7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
						8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
						9. Casing material: Plastic Height: 12 in. Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <input type="checkbox"/> RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 6 5/8 in. 362 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 316			
						10. Screen: Manufacturer's name Jet Stream Type Slotted Dia. 6 5/8 " Slot/gauze .040 Length 80 ' Set between 282 ft. and 362 ft. ft. and <input type="checkbox"/> ft. Gravel pack? Yes Size range of material 1/4 x 1/8			
						11. Static water level: Not pumped mo./day/yr. ft. below land surface Date			
						12. Pumping level below land surfaces: not pumped ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.			
						13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date			
						14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade			
						15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
						16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type Feed Lot Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No surrounds well			
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
						(Use a second sheet if needed)			
						18. Elevation:	19. Remarks:	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drlg. & Supply 145 Business name License No. Address Box 639 Garden City, KS Signed E. L. Poter Date 7-22-76 Authorized representative	
						Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST TANK

CUSTOMERS NAME Jim Miller Feed Yard PHONE NO. 7-1-76
STREET ADDRESS 1588 N. 1 Feed Lot Well
CITY & STATE Satanta, KS 67870 DRIVER Rector
COUNTY Haskell QUARTER NE SECTION 19 TOWNSHIP 30 RANGE 34

LOCATION 3100' S of office at end of feed lot

%	DRILLED		FOOTAGE	Description of Strata	362'
	From	Pay To			
	0		4	Surface	
	4		128	Sand fine med. coarse and small gravel and some large	
	128		140	Brown clay	
	140		160	Brown clay and fine sand	
	160		176	Sand fine med. coarse, small gravel, loose, used lots of water	
	176		195	Brown and blue clay	
60	195	22	212	Sand fine med. coarse, small pea gravel and small gravel, loose, used lots of water	
	212		220	Brown clay and sand sts.	
35	220	20	240	Sand fine med. coarse, small gravel and fine sandy clay	
75	240	120	360	Sand fine med. coarse, med. to small gravel, ragged in places, used lots of water (very good)	
	360		365	Clay and lime rock	
	365		368	Brown clay	
	368		375	Sand and gravel, clay and lime rock	
	375		380	Brown clay	
		162			
				CASING SCHEDULE	
				Set 362 ft. 6 5/8" Plastic Casing	
				362-282 Perforation	
				282- 0 Plain	
				1 cap on bottom	
				Gravel Pack: #1 coarse & 8-12	
				22 sacks Revert	
				2 gal. chlorine	
				1 - 6" pitless adapter left at location to be installed	

RDEN CITY, KANSAS

HENKLE DRILLING & SUPPLY CO., INC.

ONE 276-3270

IRRIGATION HEADQUARTERS

ST HOLES*****STOCK WELLS*****IRRIGATION AND DRAINAGE