


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Haskell	Township name Dudley	Fraction NE,NE,NW	Section number 20	Town number T-30-S	Range number R-34-W
Distance and direction from nearest town or city: 1 1/2 mi. southwest, 2 1/2 mi. west of Satana, Kansas				3 Owner of well: L. C. Black Address: Rt. 1, Satana, Kansas 67870		
Locate with "X" in section below: 				Sketch map:		
2				4 Well depth: 380 ft. Date of completion 6-17-75 Well diameter 9 in.		
Type and color of material				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Overburden				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
Sand & Gravel				7 Casing: Material RMP Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. Diam. 5 in. to 340 ft. depth Weight 320 lbs./ft. Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Clay				8 Screen: Manufacturer Jess & Lowell Type RMP Dia. 5 in. Wire/gauze 1/16 Length 40 ft. Set between 340 ft. and 380 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/8		
				9 Static water level: 211 ft. below land surface Date 6-17-75		
				10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 60 g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____		
				12 Well head completion: 18 in. <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 3 ft. to 13 ft.		
				14 Nearest source of possible contamination: none ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(use a second sheet if needed)						
16 Remarks: elevation Well is to be completed by Friesen Windmill of Meade, Kansas. Topography: <input type="checkbox"/> Hill Well located in pasture. <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. T & W Water Well Ser. 142 Business name ____ License No. ____ Address Box 816 Liberal, KS Signed C. W. Waggoner Date 6-17-75 Authorized representative		